

FINAL

TECHNICAL MEMORANDUM 4.2 - THICKENING MANAGEMENT

NEW Water Facility Plan

B&V PROJECT NO. 402658

PREPARED FOR



1 JULY 2021



Table of Contents

1.0	Introduction	1-1
1.1	Drivers for Thickening Improvements	1-1
1.2	Improvement Assessment.....	1-2
1.3	Relationship to overall Facility Plan	1-2
2.0	Process Configurations for Solids Thickening	2-1
2.1	Primary Sludge Management.....	2-2
2.2	Process Configurations.....	2-3
2.2.1	Process Configuration 1a – Current Operation.....	2-3
2.2.2	Configuration 1b – Current Operation, modified DPF PTU operation	2-4
2.2.3	Configuration 2a – Separate thickening for all streams.....	2-5
2.2.4	Configuration 2b – Separate thickening for all streams, modified DPF PTU operation.....	2-6
2.2.5	Configuration 3a - Cothickening	2-7
2.2.6	Configuration 3B – Cothickening, modified DPF PTU operation.....	2-8
2.3	Additional Improvements	2-9
2.4	Process Configuration Conclusions	2-9
3.0	Solids Production Projections	3-1
3.1	Approach for Solids Projections	3-1
3.2	Primary Sludge Production.....	3-2
3.3	GBF WAS Production.....	3-2
3.4	DPF WAS Production.....	3-3
3.5	Co-Thickening.....	3-3
3.6	Solids Production for Process Sizing	3-4
4.0	Nutrient Harvesting Considerations	4-1
5.0	Selective Wasting Considerations	5-1
6.0	Equipment Feasibility Evaluation	6-1
6.1	Equipment Technologies for Evaluation.....	6-1
6.2	Equipment sizing	6-2
6.3	Equipment cost Comparison	6-5
6.4	Equipment Conclusions.....	6-7
7.0	Infrastructure Package Capital Cost Estimates	7-1
7.1	Basis for Infrastructure Packages	7-1
7.2	Thickening Building Configuration	7-1
7.3	Capital Cost Estimates.....	7-4
7.3.1	Additional Improvements	7-5
7.4	Infrastructure Package summary.....	7-7
8.0	Thickening Recommendations	8-1

Appendix A. Solids Production Projections.....A-1
Appendix B. Manufacturer’s Proposal.....B-1
Appendix C. Capital Cost Estimates C-1

LIST OF TABLES

Table 2-1 Summary of Proposed Alternatives 2-2
 Table 3-1 Dynamic, 10-Year Scenario Operational Data..... 3-1
 Table 3-2 Primary Sludge Flow Rates and Mass Loads for Two Loading Scenarios at Four Different Percentiles for All Process Configurations Simulated 3-2
 Table 3-3 Green Bay WAS Flow Rates and Mass Loads Four Different Percentiles for all Configurations Simulated..... 3-2
 Table 3-4 De Pere WAS Flow Rates and Mass Loads Four Different Percentiles Assuming No Primary Sludge (Configurations 1a,2a, and 3a)..... 3-3
 Table 3-5 De Pere WAS Flow Rates and Mass Loads Four Different Percentiles Assuming Primary Sludge is Added (Configurations 1b, 2b, and 3b)..... 3-3
 Table 3-6 Mechanical Co-thickening Advantages and Disadvantages..... 3-4
 Table 3-7 Total Solid Production for Configuration 3a Cothickening..... 3-4
 Table 3-8 Total Solid Production for Configuration 3b Cothickening 3-4
 Table 3-9 Flow Rates and Mass Loads..... 3-5
 Table 3-10 Design Basis for Required Flow Streams for Each Configuration..... 3-6
 Table 6-1 Total Number of Units Required for Each Sludge Stream for Each Configuration..... 6-3
 Table 6-2 Number of Units Required, Equipment Cost, Estimated 20-Year O&M, and Total LCC for Each Equipment Alternative and Process Configuration 6-5
 Table 6-3 Operation and Maintenance Cost Assumptions 6-6
 Table 7-1 Thickener Requirements for Process Configurations..... 7-1
 Table 7-2 Multipliers Used to Determine Total Capital Costs..... 7-4
 Table 7-3 Capital Cost Estimates for the Main Infrastructure Packages 7-5
 Table 7-4 Capital Cost Estimates for Additional Package 1 and 2 Related to GT Rehabilitation 7-5
 Table 7-5 Capital Cost Estimates for Thickened Sludge Wet Well and Pumping Improvements..... 7-6
 Table 7-6 Summary of Potential Infrastructure Packages 7-7
 Table 8-1 Recommended Thickening Infrastructure Package 8-1

LIST OF FIGURES

Figure 2-1 Surface Overflow Rates for Gravity Thickeners with Primary Sludge at 0.25% Solids..... 2-3
 Figure 2-2 Process Flow Diagram for Configuration 1a..... 2-4
 Figure 2-3 Process Flow Diagram for Configuration 1b (PTUs Represented by Primary Clarifiers)..... 2-5

Figure 2-4	Process Flow Diagram for Configuration 2a.....	2-6
Figure 2-5	Process Flow Diagram for Configuration 2b (PTUs Represented by Primary Clarifiers).....	2-7
Figure 2-6	Process Flow Diagram for Configuration 3a.....	2-8
Figure 2-7	Process Flow Diagram for Configuration 3b (PTUs Represented by Primary Clarifiers).....	2-9
Figure 4-1	Impact of Ending Soluble Phosphorus Concentration in the Harvester on Phosphorus Harvested	4-2
Figure 6-1	Summary of Total Units Required for each Process Configuration	6-5
Figure 6-2	Grouped Bar Chart Showing Equipment, O&M NPV, and Total Costs for Each Alternative and Process Configuration	6-7
Figure 7-1	Conceptual Layout for Five 2-m GBTs in the Existing Thickening Building	7-2
Figure 7-2	Conceptual Layout for Five RDTs in the Existing Solids Thickening Building.....	7-3
Figure 7-3	Conceptual Layout for Six RDTs in the Existing Solids Thickening Building	7-3
Figure 7-4	Conceptual layout for 3 M GBTs.....	7-4
Figure 7-5	Conceptual Modification for Thickened Sludge Wet Well Modifications (Similar for Two Wells)	7-6

APPENDICIES

Appendix A	Solids Production Projections
Appendix B	Manufacturing Proposals
Appendix C	Capital Cost Estimates

1.0 Introduction

The Green Bay Metropolitan Sewerage District, operated under the brand name of NEW Water, collects and treats wastewater from 15 communities in a service area encompassing over 285 square miles with an estimated population of approximately 237,000 in 2019. The NEW Water facility is comprised of the Green Bay Facility (GBF) and the De Pere Facility (DPF). The NEW Water treatment facilities receive domestic, commercial, and industrial wastewater as well as hauled-in waste (HW)/high strength waste (HSW). NEW Water administers an industrial pretreatment program that regulates industrial contributors.

The GBF treated an average of 36.6 mgd of total wastewater in 2019 with a liquid treatment train consisting of influent pumping, screening, primary clarification, primary sludge grit removal, activated sludge configured for enhanced biological phosphorus removal (EBPR), secondary clarification, and disinfection with sodium hypochlorite and dechlorinated with sodium bisulfate. The solids handling treatment train includes sludge thickening with gravity belt thickeners and a thickening centrifuge followed by anaerobic digestion with co-digestion of high strength waste (HSW), centrifuge dewatering, and ending with solids drying and incineration. The GBF receives hauled waste (HW), which is screened and discharged to the plant influent and HSW, which is fed to the digesters. Industrial wastewater flows are pumped to the plant from Proctor & Gamble and Fox River Fiber.

The DPF treated an average of 8.8 mgd in 2019 of wastewater with a treatment train consisting of screening, influent pumping, grit removal, activated sludge configured for enhanced biological phosphorus removal (EBPR), intermediate clarification, final clarification, tertiary sand filters and UV. An industrial forcemain pumps waste from the Fox River Fiber industrial customer downstream of grit removal. Waste activated sludge (WAS) is pumped to the GBF for biosolids processing via a forcemain. In addition, there is an interplant transfer forcemain to the GBF, which provides some flexibility to send DPF influent to the GBF interceptor system for treatment at the GBF.

As part of a full-plant facility plan, determining how to manage solids is critical to ensuring the adequate treatment of wastewater. The purpose of Technical Memorandum 4.2 (TM 4.2) is to summarize the projected solids production rates as well as present the most feasible alternatives for the Green Bay Metropolitan Sewerage District (NEW Water) Facility Plan. The specific objectives of TM 4.2 are:

1. Simulate ten years of historical data using a previously calibrated and validated model at each of the four future loading conditions.
2. Assess three potential alternatives for sludge thickening of waste activated sludge (WAS) thickening and primary sludge (PS) thickening.
3. Provide projected capital and operational costs for each alternative.
4. Recommend which alternative should be implemented going forward.

1.1 Drivers for Thickening Improvements

The GBF primary sludge, GBF WAS, and DPF WAS are all thickened prior to digestion. During the planning horizon of the facility plan, there are several major drivers for pre-digestion solids thickening improvements:

- Industrial user growth at the GBF: expansion of Green Bay Packaging is currently under construction, and will increase influent flows and solids production by 2025.
- Aging equipment: the existing gravity belt thickeners used for WAS thickening and the primary sludge gravity thickeners are over 20 years old and lack adequate odor mitigation components.
- Operational limitations: the centrifuge installed as part of the recent solids expansion for primary sludge thickening has proved to be operationally challenging with long repair part lead times.
- Growth in the DPF service area: residential growth will be occurring in the DFP service area over the next 10 to 20 years, increasing solids production rates.
- Resource Recovery and Energy Efficiency (R2E2) operation: to achieve the energy targets for the R2E2 facilities, a net thickened solids concentration of 6 percent is required.
- Nutrient harvesting: current coagulant loadings from industrial users to the GBF and DPF have limited EBPR performance, and thus limit the extractability of phosphorus from biosolids; simplifying operations to avoid thickening prior to P-release in the future would be beneficial.

1.2 Improvement Assessment

Assessment of improvements to these drivers were developed to provide NEW Water with increased flexibility, as well as required capacity, for the next 20 years. Several process configurations were developed, along with required thickening components for each infrastructure package. To assess improvements, the following steps are recommended:

- Identify process configurations for thickening operation.
- Project future solids production for each configuration.
- Evaluate equipment solutions to provide required capacity and flexibility.
- Develop capital costs for full infrastructure packages.
- Recommend thickening package for implementation.

1.3 Relationship to overall Facility Plan

This TM has been developed as part of Task 4 of the Facility Plan. Task 1 of the Facility Plan is related to project management at execution. Task 2 of the Facility Plan focused on developing the existing conditions for the NEW Water facilities. In Task 2, the following components are tied to the overall thickening management evaluation:

- TM 2.1: Flows and Loads – the future conditions for both the DPF and GBF are used for solids projections
- TM 2.3: Process Model – the process model was used to develop projections for solids production at both facilities in the future
- TM 2.4: Gap Analysis – infrastructure gaps identified in the solids thickening area will be addressed as part of the thickening improvements

Task 3 of the Facility Plan is currently being completed to identify future drivers for NEW Water. Within Task 4, solutions are being developed to address the gaps identified in Task 2 along with the

vision developed in Task 3. There will be several evaluations in Task 4 that are impacted by decisions presented for thickening. As the Facility Plan progresses, these additional evaluations will be completed to develop a comprehensive Facility Plan. Key related infrastructure evaluations that are impacted by thickening decisions are:

- Influent screening and grit management
- Aeration system and nutrient removal improvements
- Whole plant odor control
- Whole plant nutrient and energy balance
- De Pere long term vision

The recommendations developed as part of the TM, and other Task 4 efforts, will be combined as part of Task 5 to develop a comprehensive capital improvements plan and infrastructure roadmap for NEW Water.

2.0 Process Configurations for Solids Thickening

Process configurations were developed to manage the three unthickened sludge streams for NEW Water:

- GBF primary sludge (PS)
- GBF WAS
- DPF WAS

The three main process configurations are:

- Current operation: primary sludge thickened separately, GBF, and DPF WAS combined.
- Separate sludge streams: all three sludge streams management separately.
- Co-thickening: all sludge streams combined prior to mechanical thickening.

For the DPF, there are two key aspects related to solids production. The first is related to WAS flows. WAS from the DPF is pumped in one of two ways: wasting through return activated sludge (RAS) diversion or by wasting from the mixed liquor (ML). RAS wasting occurs unless wasting flows drop below 250 gallons/minute (gpm). This flow rate results in too low of a flow to maintain adequate velocity in the sludge transfer line to the GBF. When flows are less than 250 gpm, which occurs approximately 10 to 15 percent of the year, ML wasting is operated until flow rates increase high enough. This operational strategy is addressed through process modeling and does not impact the overall process configurations.

The second unique aspect of the DPF is the management of sludge generated by the preliminary treatment units (PTUs). The PTUs are designed for grit removal; however, it was noted that when influent flows are below 15 mgd, the PTUs achieve 30 percent total suspended solids removal. Flows are less than 15 mgd at the DPF a majority of time, and therefore these solids are generated for the majority of the year. Currently, this removed TSS is recycled back to the aeration basins, where it is incorporated into the activated sludge process and eventually the WAS. As an alternative to this operation, solids production will be evaluated assuming the TSS stream from the PTUs is being added to the WAS stream, and not to the activated sludge process. Under this scenario, it was assumed that the PTUs remove 30 percent of influent TSS when flows were below 15 mgd, and this “primary” sludge would have a concentration between 0.25 and 0.50 percent to facilitate sludge dewatering. This “primary” sludge has a high flow rate, limiting the need to operate in the ML wasting strategy.

When the two different PTU strategies at DPF are combined with each of the main process configurations, a total of six configurations are possible in the future for NEW Water. The main process configurations identified for evaluation are summarized in Table 2-1. These process configurations will be combined with solids projections at the GBF and the DPF to develop infrastructure packages to meeting NEW Water’s current and future needs. Primary sludge management, process configurations, and additional solids improvements all need to be identified to develop solids production projections. In addition to the thickening evaluation and recommendations, a long-term evaluation of scum management and movement at both facilities will be recommended as part of the overall Facility Plan.

Table 2-1 Summary of Proposed Alternatives

Process	GBF PS Approach	GBF WAS Approach	DPF PTU Sludge Approach	DPF WAS Approach
Configuration 1a Combined WAS, separate PS	Separate Mechanical Thickening	Mixed with DPF WAS prior to Mechanical Thickening	Added back to DPF aeration basins	Mixed with GBF WAS prior to Mechanical Thickening
Configuration 1b Combined WAS, separate PS, DPF PTU modification	Separate Mechanical Thickening	Mixed with DPF WAS prior to Mechanical Thickening	Combined with DPF WAS prior to pipeline	Mixed with GBF WAS prior to Mechanical Thickening
Configuration 2a All sludge thickened separately	Separate Mechanical Thickening	Separate Mechanical Thickening	Added back to DPF aeration basins	Separate Mechanical Thickening
Configuration 2b All sludge thickened separately, DPF PTU modification	Separate Mechanical Thickening	Separate Mechanical Thickening	Combined with DPF WAS prior to pipeline	Separate Mechanical Thickening
Configuration 3a Co-thickening of all sludge	Co-thickening	Co-thickening	Added back to DPF aeration basins	Co-thickening
Configuration 3b Co-thickening of all sludge, DPF PTU modification	Co-thickening	Co-thickening	Combined with DPF WAS prior to pipeline	Co-thickening

2.1 Primary Sludge Management

For the process configurations presented in Table 2-1, GBF primary sludge is assumed to have a solids concentration of at least 2 percent and up to 3 percent TS. This can be achieved with the primary clarifiers, but this option would require the construction of new headworks. Alternatively, existing gravity thickeners (GTs) can be utilized to pre-thicken the primary sludge from 0.25 percent TS to 2 percent TS. This would have the additional benefit of grease capture in the GTs, reducing the grease load to the mechanical thickening.

To assess the number of GTs for this operational strategy, surface overflow rates (SORs) were calculated at each simulated year assuming PS had 0.25 percent solids and a GT diameter of 45 feet, with either two or four GTs in operation. As shown in Figure 2-1, with two GTs in operation, the SOR would be near the top end of typical design ranges through 2040. Results are shown in box-and-whisker plots, where the bottom of the box is the 25th percentile, the middle line is the median (50th percentile) and the top of the box is the 75th percentile. Whiskers extend to the largest and smallest values that are not considered outliers. Outliers are values which are more extreme than the inner fences; inner fences are calculated by determining the range between the 25th and 75th percentiles (i.e., the interquartile range, IQR) and multiplying that by 1.5. The inner fences extend beyond the 25th and 75th percentiles by this calculated value. Boxes are colored according to the projected year being simulated. White dots are means of each data set. These design ranges are typical with targets of 6 percent thickened solids (TS), and not 2 percent TS.




Figure 2-1 Surface Overflow Rates for Gravity Thickeners with Primary Sludge at 0.25% Solids

Based on process capacity, two GTs are sufficient to provide thickening to a 2 percent to 3 percent solids concentration. As part of the Facility Plan, it can then be decided if this 2 percent TS is achieved via primary clarifiers with a new headworks at NEW Water or via rehabilitated gravity thickeners.

2.2 Process Configurations

Based on the assumption that primary sludge would be at least 2 percent TS prior to mechanical thickening, process flow diagrams were developed for all six process configurations shown in Table 2-1.

2.2.1 Process Configuration 1a – Current Operation

This configuration assumes all WAS from GBF and DPF is combined prior to thickening (Figure 2-2). GBF PS is mechanically thickened separately prior to digestion. Thickened WAS and PS are combined prior to digestion and pumped via thickened sludge pumps to the digesters. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-2 Process Flow Diagram for Configuration 1a

2.2.2 Configuration 1b – Current Operation, modified DPF PTU operation

This configuration assumes WAS from both GBF and DPF is combined with DPF primary solids (0.25-0.5 percent consistency; comprising 39 percent of total solids flow on average) prior to thickening (Figure 2-3). The DPF primary solids are captured from the PTUs when influent flows are below 15 mgd. GBF PS is thickened separately prior to digestion. Thickened WAS and PS are combined prior to digestion and pumped via thickened sludge pumps to the digesters. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-3 Process Flow Diagram for Configuration 1b (PTUs Represented by Primary Clarifiers)

2.2.3 Configuration 2a – Separate thickening for all streams

This configuration assumes WAS from GBF and DPF are thickened separately (Figure 2-4). GBF PS is thickened separately prior to digestion. This configuration was developed to provide potential flexibility for the design and layout of sludge screening alternatives, allowing one, two, or three streams to be easily managed and screened separately. This configuration would require modifications to the thickening influent wet well to keep the two WAS stream separate. Thickened WAS and PS are combined prior to digestion and pumped via thickened sludge pumps to the digesters. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-4 Process Flow Diagram for Configuration 2a

2.2.4 Configuration 2b – Separate thickening for all streams, modified DPF PTU operation

This configuration assumes WAS from GBF and DPF are thickened separately (Figure 2-5), with the modified PTU operation at the DPF. This configuration was developed to provide potential flexibility for the design and layout of sludge screening alternatives, allowing one, two, or three streams to be easily managed and screened separately. This configuration would require modifications to the thickening influent wet well to keep the two WAS stream separate. Thickened WAS and PS are combined prior to digestion and pumped via thickened sludge pumps to the digesters. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-5 Process Flow Diagram for Configuration 2b (PTUs Represented by Primary Clarifiers)

2.2.5 Configuration 3a - Cothickening

This configuration assumes all WAS from GBF and DPF is combined prior to thickening along with GBF PS (2 percent solids) in the existing thickening wet well (Figure 2-6). Mixing would occur in the existing sludge thickening/equalization tank. This mixed sludge would be evenly split between mechanical thickening units. Thickened sludge would be pumped to the digestion process. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-6 Process Flow Diagram for Configuration 3a

2.2.6 Configuration 3B – Cothickening, modified DPF PTU operation

This configuration assumes all WAS from GBF and DPF is combined is combined with DPF primary solids along with GBF PS prior to thickening (Figure 2-7). Mixing would occur in the existing sludge thickening/equalization tank. This mixed sludge would be evenly split between mechanical thickening units. Thickened sludge would be pumped to the digestion process. Under the base scenario, the phosphorus release tank is not in operation for WAS flows.




Figure 2-7 Process Flow Diagram for Configuration 3b (PTUs Represented by Primary Clarifiers)

2.3 Additional Improvements

The process flow diagrams represent the overall process configurations for future PS and WAS thickening. There are two key additional improvements that could be applied to all these configurations to increase reliability and operability of the overall thickening operation. The first, as discussed previously, is improvements to two or four gravity thickeners. The second improvement is related to thickened sludge pumping. The current thickened sludge wet wells and thickened sludge pumps have shown rotor stator wear issues because of grit load.. There are several bends between the wet well and the pump, which can create clogging and restriction conditions from grease and scum, especially on the suction side of the pumps. An additional improvement would be related to improving the configuration of the wet well and layout of the thickened sludge pumps. The details of gravity thickener and thickened sludge transfer improvements will be discussed as part of the overall improvements evaluation, but should be noted as additional improvements with the configurations previously discussed.

2.4 Process Configuration Conclusions

Identification of the potential process configurations provides the basis for developing solids projections. Through the identification of six feasible process configurations, a full bracket of potential solids flow can be estimated. These solids production ranges can then be used to develop infrastructure packages to provide the required thickening capacity for each process configuration.

3.0 Solids Production Projections

For evaluation of infrastructure packages, a design range for solids mass and hydraulic flows for each process configuration is required. It is important that these projects account for the potential of combining solids flows and future growth scenarios. A process modeling based approach was used for projecting future solids production rates, which can then be used to identify the capacity requirements for thickening infrastructure packages for the six potential process configurations.

3.1 Approach for Solids Projections

The previously calibrated and validated process model (see TM 2.3) was used to determine projected solids production rates for the three undigested sludge streams. The model was converted to a liquids-only layout by replacing digestion and sludge thickening units with a simulated thickened digestate supernatant recycle stream.

To generate ranges of solids production rates, a 10-year dynamic simulation was completed based on historic daily concentration data for GBF and DPF for each significant growth year identified in TM 2.1 (i.e., 2020, 2025, 2040, and 2070), but with increased influent flow rates based on the year being simulated (e.g., the 2070 dynamic simulation had higher flows than the 2020 dynamic simulation). Missing data were statistically imputed by calculating pairwise and higher order correlations between inputs (e.g., flow, COD, TKN, etc.). The potential added load from Green Bay Packaging (GBP) was also assessed and SRT control was implemented more strictly (i.e., SRT was set to 18 days between November-March and was set to 10 days between April-October to achieve a nitrification safety factor of 2.5). Table 3-1 below details operational details regarding the 10-year simulations. Completing two scenarios at each design year for the number of GBF aeration basins in operation helps to provide a bracket on the WAS concentrations for the GBF.

Table 3-1 Dynamic, 10-Year Scenario Operational Data Showing Year Simulated, Inclusion/Exclusion of GBP and How Many Aeration Basin Trains were Assumed to be Online for Each Facility

Scenario	Year	GBP added	GBF North ABs online	GBF South ABs online	DPF ABs online
1	2020	No	2	1	2
2	2020	No	3	2	2
3	2025	Yes	2	1	2
4	2025	Yes	3	2	2
5	2040	Yes	3	1	2
6	2040	Yes	4	2	2
7	2070	Yes	4	2	2
8	2070	Yes	3	1	2

GBP – Green Bay Packaging; GBN – Green Bay North; GBS – Green Bay South; DP – De Pere; AB – aeration basin

For each scenario, the primary sludge, GBF WAS, and DPF WAS production for each of the six process configurations was developed. To ensure that each package assessed as part of this TM will be able to handle future loading for decades to come, four model outputs were utilized to size each alternative: 2025 25th percentile, 2025 50th percentile, 2040 50th percentile, and 2040 90th

percentile. The solids production projections for primary sludge, GBF WAS, and DPF WAS will be combined in different manners to size mechanical thickening equipment.

3.2 Primary Sludge Production

Table 3-2 provides a summary of the PS design characteristics for the GBF. The PS flow design considers a bracketed range of potential concentrations (i.e., 2 percent or 3 percent solids) and flows. For design purposes, flow rates varied between 150-220 gpm at 2 percent solids, 100-140 gpm at 3 percent solids, and corresponding mass loads varied between 35,000-52,000 ppd (ranges of solids production provided as box-and-whisker plots in **Appendix A**) were identified for average day conditions. The flow rate at 2 percent solids will be the controlling flow for hydraulic considerations. The 2040 90th percentile value will be used for peak loading sizing, and the 2025 50th percentile will be used for average loading sizing.

Table 3-2 Primary Sludge Flow Rates and Mass Loads for Two Loading Scenarios at Four Different Percentiles for All Process Configurations Simulated

	Flow at 2% solids [gpm]	Flow at 3% solids [gpm]	Mass Load [ppd]
2025 25th	150	100	35,000
2025 50th	160	110	39,000
2040 50th	170	110	41,000
2040 90th	220	140	52,000

3.3 GBF WAS Production

Table 3-3 provides a summary of the combined WAS design characteristics for the two GBF activated sludge systems (i.e., North and South). For evaluation purposes, flow rates varied between 280-700 gpm, and corresponding mass loads varied between 28,000-39,000 ppd (box-and-whisker plots provided in Appendix A). The 90th percentile values are equivalent to maximum month loading conditions. The 2040 90th percentile value will be used for peak loading sizing, and the 2025 50th percentile will be used for average loading sizing.

Table 3-3 Green Bay WAS Flow Rates and Mass Loads Four Different Percentiles for all Configurations Simulated.

	Flow rate [gpm]	Mass Load [ppd]
2025 25th	280	28,000
2025 50th	430	31,000
2040 50th	590	33,000
2040 90th	700	39,000

3.4 DPF WAS Production

Table 3-4 provides a summary of the combined WAS design characteristics for the De Pere facility assuming no sludge diversion of PTU solids; Table 3-5 assumes that solids are diverted from the PTUs when influent flow is less than 15 mgd and combined with the reduced WAS flow rate. For evaluation, flow rates varied between 280-540 gpm for scenarios with no primary solids and 830-1,640 for scenarios with thickening. Corresponding mass loads varied between 21,000-37,000 and 27,000-45,000 ppd, respectively (see Appendix A for box and whisker plots). The large increase with the primary solids from the PTUs is due to the low solids concentration assumed for the primary sludge flow (0.25 percent solids assumed). These solids would be combined with the WAS solids and be pumped to the GBF for processing. The 90th percentile values are equivalent to maximum month loading conditions. The 2040 90th percentile value will be used for peak loading sizing, and the 2025 50th percentile will be used for average loading sizing.

Table 3-4 De Pere WAS Flow Rates and Mass Loads Four Different Percentiles Assuming No Primary Sludge (Configurations 1a,2a, and 3a)

	Flow rate [gpm]	Mass Load [ppd]
2025 25th	280	21,000
2025 50th	300	24,000
2040 50th	300	27,000
2040 90th	540	37,000

Table 3-5 De Pere WAS Flow Rates and Mass Loads Four Different Percentiles Assuming Primary Sludge is Added (Configurations 1b, 2b, and 3b)

	Flow rate [gpm]	Mass Load [ppd]
2025 25 th	830	27,000
2025 50 th	1,050	31,000
2040 50 th	1,120	33,000
2040 90 th	1,640	45,000

3.5 Co-Thickening

While gravity co-thickening is not typically recommended for primary solids and WAS, mechanical co-thickening can be used to thicken the combined solids in a single step. Thickener enclosures limited hydraulic contact time, and polymer optimization can make mechanical co-thickening a beneficial process. Enclosed thickening processes may be more attractive than open processes, due to the odor potential of the combined solids. Advantages and disadvantages are listed in

Table 3-6.

Table 3-6 Mechanical Co-thickening Advantages and Disadvantages

Advantages	Disadvantages
Single process for primary and secondary solids	Greater odor potential than separate thickening; enclosed process recommended
High solids concentrations for downstream processing	Pumping equipment must be suitable for high solids concentrations
Retains energy in solids	Capacity requirements may limit choice of mechanical thickening technology
	Additional challenges for grease management and subsequent plugging and wear on equipment.

Solids production rates for both cothickening configurations are summarized in Table 3-7 and Table 3-8, with box-and-whisker plots provided in Appendix A. The 90th percentile values are equivalent to maximum month loading conditions. The 2040 90th percentile value will be used for peak loading sizing, and the 2025 50th percentile will be used for average loading sizing.

Table 3-7 Total Solid Production for Configuration 3a Cothickening

	Flow rate [gpm]	Mass Load [ppd]
2025 25th	660	84,000
2025 50th	890	94,000
2040 50th	1,060	101,000
2040 90th	1,460	128,000

Table 3-8 Total Solid Production for Configuration 3b Cothickening

	Flow rate [gpm]	Mass Load [ppd]
2025 25th	1,210	90,000
2025 50th	1,640	101,000
2040 50th	1,880	107,000
2040 90th	2,560	136,000

3.6 Solids Production for Process Sizing

Table 3-9 provides the range of the mass loads and flow rates for the six alternative process configurations. These data will be used for preliminary sizing and evaluation of thickening equipment. The design basis for each applicable flow stream for each configuration is summarized in Table 3-10. The different flow streams for each configuration will be sized for thickening equipment in Section 6.

Table 3-9 Flow Rates and Mass Loads for Each Configuration and at Four Different Percentiles

Process Configuration	Scenario	GBF PS		GBF WAS		DPF WAS		combined WAS		CoThickened	
		Mass	Flow ¹	Mass	Flow	Mass	Flow	Mass	Flow	Mass	Flow
Configuration 1a	2025, 25 th	35,000	100	28,000	280	21,000	280	49,000	560	N/A	
	2025, 50 th	39,000	160	31,000	430	24,000	300	55,000	730		
	2040, 50 th	41,000	170	33,000	590	27,000	300	60,000	890		
	2040, 90 th	52,000	220	39,000	700	37,000	540	76,000	1,240		
Configuration 1b	2025, 25 th	35,000	100	28,000	280	27,000	830	55,000	1,110	N/A	
	2025, 50 th	39,000	160	31,000	430	31,000	1,050	62,000	1,480		
	2040, 50 th	41,000	170	33,000	590	33,000	1,120	66,000	1,710		
	2040, 90 th	52,000	220	39,000	700	45,000	1,640	84,000	2,340		
Configuration 2a	2025, 25 th	35,000	100	28,000	280	21,000	280	N/A		N/A	
	2025, 50 th	39,000	160	31,000	430	24,000	300				
	2040, 50 th	41,000	170	33,000	590	27,000	300				
	2040, 90 th	52,000	220	39,000	700	37,000	540				
Configuration 2b	2025, 25 th	35,000	100	28,000	280	27,000	830	N/A		N/A	
	2025, 50 th	39,000	160	31,000	430	31,000	1,050				
	2040, 50 th	41,000	170	33,000	590	33,000	1,120				
	2040, 90 th	52,000	220	39,000	700	45,000	1,640				
Configuration 3a	2025, 25 th	35,000	100	28,000	280	21,000	280	N/A		84,000	660
	2025, 50 th	39,000	160	31,000	430	24,000	300			94,000	890
	2040, 50 th	41,000	170	33,000	590	27,000	300			101,000	1,060
	2040, 90 th	52,000	220	39,000	700	37,000	540			128,000	1,460
Configuration 3b	2025, 25 th	35,000	100	28,000	280	27,000	830	N/A		90,000	1,210
	2025, 50 th	39,000	160	31,000	430	31,000	1,050			101,000	1,640
	2040, 50 th	41,000	170	33,000	590	33,000	1,120			107,000	1,880
	2040, 90 th	52,000	220	39,000	700	45,000	1,640			136,000	2,560

¹2025 25th percentile based on 3 percent solids concentration.

Table 3-10 Design Basis for Required Flow Streams for Each Configuration

Process Configuration	Scenario	GBF PS		GBF WAS		DPF WAS		combined WAS		CoThickened	
		Mass	Flow ¹	Mass	Flow	Mass	Flow	Mass	Flow	Mass	Flow
Configuration 1a	Average Design	39,000	160	N/A				55,000	730	N/A	
	Maximum Design	52,000	220	N/A				76,000	1,240	N/A	
Configuration 1b	Average Design	39,000	160	N/A				62,000	1,480	N/A	
	Maximum Design	52,000	220	N/A				84,000	2,340	N/A	
Configuration 2a	Average Design	39,000	160	31,000	430	24,000	300	N/A		N/A	
	Maximum Design	52,000	220	39,000	700	37,000	540	N/A		N/A	
Configuration 2b	Average Design	39,000	160	31,000	430	31,000	1,050	N/A		N/A	
	Maximum Design	52,000	220	39,000	700	45,000	1,640	N/A		N/A	
Configuration 3a	Average Design	N/A								94,000	890
	Maximum Design	N/A								128,000	1,460
Configuration 3b	Average Design	N/A								101,000	1,640
	Maximum Design	N/A								136,000	2,560

¹2025 25th percentile based on 3 percent solids concentration.

4.0 Nutrient Harvesting Considerations

The current operation strategy specified for the nutrient harvesting process consists of sending a blend of thickened PS and WAS to the P-release tank, achieving a net 2 percent solids concentration in the feed to the P-release tank. The 2 percent P-release sludge is then thickened to 6 percent solids. Feeding 2 percent solids into the P-release tank increases the phosphorus concentration in the P-release filtrate water. This concentration is a major driving force in the amount of recoverable phosphorus. Within the nutrient harvesting reactor, the ending soluble phosphorus concentration after the reaction is the driver for recoverable phosphorus. Historically, this ending soluble phosphorus concentration was 40 to 60 mg/L using magnesium chloride. Recent research by Ostara has investigated the use of magnesium oxide to drive precipitation. This chemical can reportedly achieve an ending soluble phosphorus concentration in the harvester of 10 to 30 mg/L. If this lower ending soluble phosphorus concentration is achievable, it may be feasible to send raw WAS to the P-release tank and avoid the intermediate thickening step.

A mass balance was completed to understand the impact of the ending soluble phosphorus concentration on phosphorus harvested. The following assumptions were made for the mass balance, which all assumed full EBPR functionality:

- WAS thickened before P-release
 - Phosphorus mass in WAS: 1,100 ppd (average design condition)
 - Phosphorus released in P-release tank: 35 percent of total solids phosphorus load
 - Phosphorus released in digestion: 30 percent of total solids phosphorus load
 - Solids concentration into P-release tank: 2 percent
 - Thickened solids to digestion: 6 percent
 - Pre-digestion thickening filtrate flow: 0.24 mgd
 - Dewatered cake concentration: 19 percent
 - Post digestion filtrate flow: 0.1 mgd
- Unthickened WAS to P-release
 - Phosphorus mass in WAS: 1,100 ppd (average design condition)
 - Phosphorus released in P-release tank: 35 percent of total solids phosphorus load
 - Phosphorus released in digestion: 30 percent of total solids phosphorus load
 - Solids concentration into P-release tank: 2 percent
 - Thickened solids to digestion: 6 percent
 - Pre-digestion thickening filtrate flow: 0.91 mgd
 - Dewatered cake concentration: 18 percent
 - Post digestion filtrate flow: 0.1 mgd

The difference between the thickened P-release and the WAS P-release is the pre-digestion filtrate flow. This increased flow reduces the combined soluble phosphorus concentration to 90 mg/L when raw WAS is fed to the P-release tank (combination of pre-digestion filtrate and post-digestion filtrate). For the thickened WAS operation in the P-release tank, this phosphorus concentration is 250 mg/L. The impact of the ending soluble phosphorus concentration in the harvester on the

phosphorus harvested in each scenario is shown in Figure 4-1. If the ending phosphorus concentration is 50 mg/L, the WAS thickening before P-release doubles the phosphorus harvested. If the ending concentration is 20 mg/L, there is a 20 percent reduction in the phosphorus harvested.




Figure 4-1 Impact of Ending Soluble Phosphorus Concentration in the Harvester on Phosphorus Harvested

Given the uncertainty surrounding long-term nutrient harvesting at NEW Water, it is likely not prudent to invest in thickening equipment specifically for nutrient harvesting. Based on developments related to the form of magnesium used for harvesting, it may be possible to operate without the WAS thickening prior to P-release while still harvesting a significant mass of phosphorus. For nutrient harvesting considerations, it is recommended that space be reserved for additional thickening operation; however, applied research to determine the ability to operate at a lower ending soluble phosphorus concentration and simplify the solids thickening process flow schematic should be completed.

5.0 Selective Wasting Considerations

The thickening capacity projections developed consider historical performance of both the GBF and the DPF. While the DPF thickening projections consider alternate approaches (PTU TSS stream diversion from activated sludge process), the GBF facility considers only growth projections. One challenge of the GBF secondary process is the high variability of the sludge settling characteristics, poor settleability with sludge volume indices (SVIs) greater than 200 g/mL are frequently observed. One consideration of the NEW Water Facility Plan will include an evaluation of potential alternatives to improve settling characteristics. Improved settling characteristics will provide several benefits to the GBF:

- Increased wet weather capacity of individual secondary treatment unit processes – increased clarifier solids loading rates
- Increased dry weather reliability of individual secondary treatment unit processes – increased solids loading rates allow operation at higher SRTs, increasing nitrification reliability without requiring more treatment units online
- Dry and wet weather clarifier performance – well-flocculating sludge increases the capture rate of discrete particles, decreasing effluent TSS
- Pumping energy reduction – higher settling rates and well-flucclulating sludge decrease the required underflow (RAS) rates, reduced RAS rates in-turn can increase compression settling and resulting sludge blanket concentrations

One specific technology that has shown to increase sludge settling rates is the use of hydrocyclones to implement selective wasting of the activated sludge system. The use of hydrocyclones requires reconfiguration of the WAS pumps and piping. Flow in excess of the required WAS rates are sent to the hydrocyclone units where higher density particles are separated and returned to the process. Less dense particles are then wasted to the thickening process. Under typical hydrocyclone operation 80 percent of the influent leaves through the overflow (less dense particles that are wasted) with the remaining 20 percent returning to the process. Modifications to the WAS pumping and piping may be required to meet the increased flow and backpressure requirements of the hydrocyclones.

The specific impact to the thickening processes receiving pumped WAS flows with the implementation of selective wasting is anticipated to be minimal. The sludge blanket concentrations would increase as the result of improved settling characteristics, however, the overflow of the hydrocyclones (WAS stream) is not anticipated to have an increased concentration. The combination of selective wasting and a potentially longer SRT with improved settleability could reduce the hydraulic capacity required of the thickening equipment. The equipment evaluated for the NEW Water thickening improvements was limited by hydraulic capacity rather than solids loading capacity. As part of the selective wasting, NEW Water would consider a pilot program; results of this program can be fed into any potential impacts to thickening equipment.

6.0 Equipment Feasibility Evaluation

Based on the results presented above, equipment alternatives were determined that would be able to effectively manage the projected flows and solids loads. Three technologies were examined for their feasibility to handle these loads: gravity belt thickeners (GBTs, 2-meter and 3-meter), rotary drum thickeners (RDTs), and centrifuges. These three technologies were identified during the preliminary workshop with NEW Water in February 2020. The initial alternative comparison is based on equipment only, comparing the three technologies in term of capital and life cycle costs as well as non-cost benefits. Full infrastructure configuration costs will be completed in the following section.

6.1 Equipment Technologies for Evaluation

The three equipment technologies considered each have benefits and drawbacks for the three sludge streams considered. The following summarizes each technology with the respect to the sludge streams considered.

- Gravity Belt Thickeners (GBTs)
 - Technology requires the most footprint per unit of capacity of the three technologies considered.
 - Ability to thicken all flow streams (WAS, PS, Co-Thickening), one unit could act as a swing unit for both WAS and PS redundancy, although this is not common for GBTs
 - Equipment is familiar to both operations and maintenance staff
 - Least adaptable to odor control required for primary sludge and/or co-thickening
 - Units can be covered with a plexiglass cover (assumption used for cost estimates) but this limits visibility of sludge consistency
 - For NEW Water, enclosed GBTs were evaluated, which can provide accessibility for odor control
 - Equal to or the highest polymer requirements for equivalent thickening of the three technologies considered
- Rotary Drum Thickeners (RDT)
 - Relatively small footprint requirement per unit capacity of the three
 - Ability to thicken all flow streams (WAS, PS, Co-Thickening), one unit could act as a swing unit for both WAS and PS redundancy
 - Equipment is odor control ready as a base package and fully enclosed, reducing odor emissions
 - Equal to or the highest polymer requirements for equivalent thickening of the three technologies considered
- Centrifuge
 - Technology is equal to or the lowest footprint requirement per unit capacity of the three

- Technology not capable of handling all three flow streams (current unit not capable of handling primary sludge), additional redundancy would need to be considered for primary sludge thickening technology selected
- Lowest polymer use of three technologies considered
- Equipment is odor control ready as a base package and fully enclosed, reducing odor emissions

6.2 Equipment sizing

Preliminary manufacturer proposals for each technology are included in **Appendix B**. The number of units required for each technology (and therefore, the equipment cost) was determined by comparing the unit's capacity to the established design flows and load for each process configuration. From Section 3, the peak design flow and load was the 90th percentile loading in 2040; average design loading was the 50th percentile loading in 2025. Each technology for each process configuration assumed one additional shared unit for redundancy. This assumption can be further explored with NEW Water. For alternatives that considered WAS and PS thickening separately, the unit would be a swing unit accommodating redundancy for both processes. Therefore, equipment estimates were for the total firm units, plus one total redundancy. Piping would be included for swing redundancy. The total number of units with this redundancy is presented in Table 6-1 for each sludge stream, with a summary presentation in Figure 6-1.

Table 6-1 Total Number of Units Required for Each Sludge Stream for Each Configuration

	Design Range		2 M GBTs			3 M GBTs			RDTs			Centrifuges		
	Average (gpm)	Max (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)
Primary Sludge														
Configuration 1a	160	220	1	400	660	1	600	900	1	420	600	1	500	920
Configuration 1b	160	220	1	400	660	1	600	900	1	420	600	1	500	920
Configuration 2a	160	220	1	400	660	1	600	900	1	420	600	1	500	920
Configuration 2b	160	220	1	400	660	1	600	900	1	420	600	1	500	920
Configuration 3a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
GBF WAS														
Configuration 1a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 1b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 2a	430	700	2	800	1,320	1	600	900	2	840	1,200	1	500	920
Configuration 2b	430	770	2	800	1,320	1	600	900	2	840	1,200	1	500	920
Configuration 3a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
DPF WAS														
Configuration 1a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 1b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 2a	300	540	1	400	660	1	600	900	1	420	600	1	500	920
Configuration 2b	1,050	1,640	2	800	1,320	2	1,200	1,800	2	840	1,200	2	1,000	1,840
Configuration 3a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3b	-	-	-	-	-	-	-	-	-	-	-	-	-	-

	Design Range		2 M GBTs			3 M GBTs			RDTs			Centrifuges		
	Average (gpm)	Max (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)	Unit	Avg Cap. (gpm)	Max Cap. (gpm)
Combined WAS														
Configuration 1a	730	1,240	3	1,200	1,980	2	1,200	1,800	3	1,260	1,800	2	1,000	1,840
Configuration 1b	1,480	2,340	4	1,600	2,640	3	1,800	2,700	4	1,680	2,400	3	1,500	2,760
Configuration 2a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 2b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Co-thickened Solids														
Configuration 1a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 1b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 2a	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 2b	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Configuration 3a	890	1,460	3	1,200	1,980	2	1,200	1,800	3	1,260	1,800	2	1,000	1,840
Configuration 3b	1,640	2,560	4	1,600	2,640	3	1,800	2,700	4	1,680	2,400	3	1,500	2,760
Total Thickening Units (Required for Capacity + 1)														
Configuration 1a	890	1,460	5	1,600	2,640	4	1,800	2,700	4	1,680	2,400	3	1,500	2,760
Configuration 1b	1,640	2,560	6	2,000	3,300	5	2,400	3,600	6	2,100	3,000	5	2,000	3,680
Configuration 2a	890	1,460	5	1,600	2,640	4	1,800	2,700	4	1,680	2,400	3	1,500	2,760
Configuration 2b	1,640	2,560	6	2,000	3,300	5	2,400	3,600	6	2,100	3,000	5	2,000	3,680
Configuration 3a	890	1,460	4	1,200	1,980	3	1,200	1,800	4	1,260	1,800	3	1,000	1,840
Configuration 3b	1,640	2,560	5	1,600	2,640	4	1,800	2,700	5	1,680	2,400	4	1,500	2,760




Figure 6-1 Summary of Total Units Required for each Process Configuration

For Process Configurations 1b and 2b, where the modified PTU operation is included with separate thickening options, the sizing for the mechanical primary sludge thickener is the main cause for an increased number of thickening units as compared to Process Configuration 3b. It was assumed that all thickening units should be the same model for maintenance simplicity. However, this results in excess capacity in the primary sludge thickening unit. In Configuration 3b, where WAS is blended with PS prior, this excess capacity is captured, and thus fewer overall thickeners are required.

6.3 Equipment cost Comparison

The estimated 20-year operation and maintenance (O&M) was determined using a net present value approach (NPV) at the 2025 50th percentile loading condition assuming: cost of electricity is \$0.07/kWh, cost of polymer is \$3.00/lb, 2 percent of capital cost for annual maintenance, 2 percent inflation, 20-year life cycle, and 3 percent discount rate (Table 6-3). The total life cycle costs (LCC) are the sum of the equipment cost and the O&M (Table 6-2 and Figure 6-2).

Table 6-2 Number of Units Required, Equipment Cost, Estimated 20-Year O&M, and Total LCC for Each Equipment Alternative and Process Configuration

Configuration		Alternative			
		2M GBTs	3M GBTs	RDTs	Cent.
Configuration 1a Combined WAS, Separate PS	Units Required	5	4	5	4
	Equipment Cost	\$1,125,000	\$1,600,000	\$1,025,000	\$2,555,600
	20-year O&M NPV	\$6,050,880	\$6,013,971	\$6,886,311	\$7,554,794
	Total LCC	\$7,175,880	\$7,613,971	\$7,911,311	\$10,110,394

Configuration		Alternative			
		2M GBTs	3M GBTs	RDTs	Cent.
Configuration 1b Combined WAS, Separate PS, DPF PTU modification	Units Required	6	5	6	5
	Equipment Cost	\$1,380,000	\$2,000,000	\$1,230,000	\$3,194,500
	20-year O&M NPV	\$6,463,710	\$6,426,801	\$6,426,801	\$8,969,777
	Total LCC	\$7,843,710	\$8,426,801	\$7,656,801	\$12,164,277
Configuration 2a All sludge thickened separately	Units Required	5	4	5	4
	Equipment Cost	\$1,125,000	\$1,600,000	\$1,025,000	\$2,555,600
	20-year O&M NPV	\$6,037,504	\$6,000,595	\$5,994,444	\$7,487,084
	Total LCC	\$7,162,504	\$7,600,595	\$7,019,444	\$10,042,684
Configuration 2b All sludge thickened separately, DPF PTU modification	Units Required	6	5	6	5
	Equipment Cost	\$1,575,000	\$2,000,000	\$1,435,000	\$3,194,500
	20-year O&M NPV	\$6,481,339	\$6,425,976	\$6,425,976	\$8,994,215
	Total LCC	\$8,056,339	\$8,425,976	\$7,860,976	\$12,188,715
Configuration 3a Co-thickening of all sludge	Units Required	4	3	4	4
	Equipment Cost	\$900,000	\$1,200,000	\$820,000	\$2,555,600
	20-year O&M NPV	\$2,943,306	\$3,224,852	\$2,844,852	\$5,069,092
	Total LCC	\$3,843,306	\$4,424,852	\$3,664,852	\$7,624,692
Configuration 3b Co-thickening of all sludge, DPF PTU modification	Units Required	5	4	5	4
	Equipment Cost	\$1,150,000	\$1,600,000	\$1,025,000	\$2,555,600
	20-year O&M NPV	\$3,330,747	\$3,762,293	\$3,181,141	\$6,132,311
	Total LCC	\$4,480,747	\$5,362,293	\$4,206,141	\$8,687,911

Table 6-3 Operation and Maintenance Cost Assumptions

Cost Category	All Thickening		
	GBT	RDT	Centrifuge
WAS Polymer Use, lb/ton	8	10	3
PS Polymer Use, lb/ton	8	8	3
Co-Thickening Polymer Use, lb/ton	8	8	3
Cost of Polymer, \$/lb	3		
Power Use, HP/unit	3	3	175 ¹
Cost of Electricity, \$/kWh	0.07		

Cost Category	All Thickening		
	GBT	RDT	Centrifuge
Maintenance, % of capital	2	2	2
Maintenance, \$/year/unit	\$4,500	\$4,100	\$12,800
Inflation Rate, %	2		
Discount Rate, %	3		

¹ Power costs used a 0.2 kW/gpm value for centrifuges to account for turndown




Figure 6-2 Grouped Bar Chart Showing Equipment, O&M NPV, and Total Costs for Each Alternative and Process Configuration

6.4 Equipment Conclusions

The technologies evaluated have a clear separation between RDTs/GBTs (which were within 5 percent equipment and LCC of each other) and the centrifuge technology. Centrifuges represent the high cost alternative and provide minimal non-cost benefits compared to the other two

technologies. Due to the equipment comparisons, centrifuges have been eliminated for further consideration as a thickening technology for infrastructure packages. RDTs and GBTs both represent viable technologies for NEW Water and should be considered further. The RDTs, 2 M GBTs, and 3 M GBTs are near equivalent in terms of life cycle costs. However, RDTs may offer advantages in terms of space requirements and flexibility to treat multiple flow streams with low odor emissions. The following sections will consider full infrastructure packages for both RDTs and 2 M GBTs. These two technologies were the focus of the evaluation given space constraints, future flexibility, and the more common 2 M GBT equipment. A final decision between these three technologies can be made during preliminary design.

7.0 Infrastructure Package Capital Cost Estimates

The full cost of an upgrade requires consideration of non-equipment costs (e.g., piping, electrical, and labor). Using the feasible alternatives identified above, full infrastructure package capital costs were estimated.

7.1 Basis for Infrastructure Packages

When the number of required thickeners (2 M GBTs or RDTs) is compared for the six process configurations identified, four of the six process configurations are compatible with five total thickeners (which includes one redundant unit), while two configurations require six thickeners. This is summarized in Table 7-1. Piping flexibility would provide the ability to operate in the Process Configurations 1a, 2a, 3a, and 3b. For Process Configurations 1b and 2b, five thickeners would provide the capacity to thicken the solids loads, but there would be no redundancy. If Process Configurations 1b or 2b were implemented, the flexibility to pivot to cothickening when a unit was down for maintenance would be a potential option. Otherwise, six thickeners would be required. Based on the required number of units, two infrastructure packages were developed for solids thickening that address all six process configurations:

- Infrastructure Package 1: Five thickeners
- Infrastructure Package 2: Six thickeners

Table 7-1 Thickener Requirements for Process Configurations

Process Configuration	Number of Thickeners (one redundant Unit)
Configuration 1a Combined WAS, separate PS	Infrastructure Package 1 Five 2 M GBTs or five RDTs
Configuration 1b Combined WAS, separate PS, DPF PTU modification	Infrastructure Package 2 Six 2 M GBTs or six RDTs
Configuration 2a All sludge thickened separately	Infrastructure Package 1 Five 2 M GBTs or five RDTs
Configuration 2b All sludge thickened separately, DPF PTU modification	Infrastructure Package 2 Six 2 M GBTs or six RDTs
Configuration 3a Co-thickening of all sludge	Infrastructure Package 1 Five 2 M GBTs or five RDTs
Configuration 3b Co-thickening of all sludge, DPF PTU modification	Infrastructure Package 1 Five 2 M GBTs or five RDTs

7.2 Thickening Building Configuration

For the infrastructure package capital cost, the equipment cost and LCC for GBTs and RDTs were within 5 percent of each other. When the existing footprint of the facility is examined, conceptual layouts for five GBTs and five RDTs appear to fit in the existing solids thickening building (Figure 7-1 and Figure 7-2, respectively). Therefore, for Infrastructure Package 1, it is recommended that five thickeners be assumed for capital planning, with the final decision between GBTs and RDTs reserved for preliminary design. One important note for the RDTs is that some manufacturers require significant clearance for maintenance of internal components. The Andritz RDT requires a 15-foot clearance on the discharge of the RDT. However, the Parkson RDT only requires a 3-foot

clearance. For RDTs, the site-specific constraints will likely be a key factor in the final equipment section if RDTs are ultimately selected for design.

For Infrastructure Package 2, where six total thickening units are required, it would not be possible to accommodate this with GBTs. Six RDTs are feasible, but increase the overall footprint (Figure 7-3). For Infrastructure Package 2, which provides increased flexibility for operational strategies for NEW Water, preliminary design would need to move forward only considering RDTs.

Although not a focus of the evaluation, a layout using four, 3 M GBTs was developed (Figure 7-4). The four 3 M GBTs limited future expandability, and cannot meet all six of the conditions developed for consideration. Given the similar capital and operating costs as compared to the 2 M GBT and RDT options, the 3 M GBT option was not carried to final capital cost estimating.




Figure 7-1 Conceptual Layout for Five 2-m GBTs in the Existing Thickening Building




Figure 7-2 Conceptual Layout for Five RDTs in the Existing Solids Thickening Building




Figure 7-3 Conceptual Layout for Six RDTs in the Existing Solids Thickening Building




Figure 7-4 Conceptual layout for 3 M GBTs

7.3 Capital Cost Estimates

Total capital costs were determined using the percentages listed in Table 7-2. Infrastructure package project capital cost estimates are summarized in Table 7-3. These cost estimates include the major infrastructure indicated, with additional multipliers and factors shown in Table 7-2. The potential capital cost range represents the range of project costs as defined for a Class 4 cost estimate (AACE International Recommended Practice No. 18R-97), with the range representing 85 percent to 125 percent of that most probable capital cost. The thickening equipment is being installed in an existing thickening building, and therefore no major building modifications related to code requirements were assumed. Odor mitigation is included in the form of duct work and vent fans to manage odor in the thickening building. See Section 7.3.4.1 for additional odor control discussion. Additional capital cost estimate details are included in **Appendix C**.

Table 7-2 Multipliers Used to Determine Total Capital Costs

Component	Multiplier	Value multiplied against
Installation	30%	Equipment
Mechanical	20%	Equipment + Installation
Electrical and I&C	20%	Equipment + Installation
Contractor Overhead and Profit	25%	Installed equipment cost
Contingency	50%	Installed cost + Overhead
Engineering	25%	Installed cost + Overhead + Contingency

Table 7-3 Capital Cost Estimates for the Main Infrastructure Packages

Infrastructure Package	Major Infrastructure	Potential Capital Cost Range	Most Probable Capital Cost
Package 1 Configuration 1a, 2a, 2a, 3b	<ul style="list-style-type: none"> • Five GBTs or RDTs • Required platforms and piping • Thickened sludge feed pumps • Odor mitigation 	\$5.7M to \$8.3M	\$6.7M
Package 2 All six configurations	<ul style="list-style-type: none"> • Six RDTs • Required platforms and piping • Thickened sludge feed pumps • Odor mitigation 	\$6.6M to \$9.7M	\$7.8M

7.3.1 Additional Improvements

7.3.1.1 Gravity Thickening

There are two additional improvements that could be added to the capital project for sludge thickening. As discussed, the mechanical thickening of primary sludge is based on a feed concentration of at least 2 percent solids. This requires either thickening in the primary clarifiers (which would require a new headworks facility at the GBF) or pre-thickening with the GTs. To improve the operability of the GTs and modify the flow path to feed the gravity thickened sludge to the mechanical thickening, the following improvements would be recommended:

- New gravity thickener mechanisms
- New aluminum covers for odor mitigation
- Improvements to interior concrete (assumed due to age)
- New piping to convey gravity thickened primary sludge to the unthickened sludge wet well, where piping would go to both wet wells for flexibility; piping would be in the existing tunnel system

Based on the SOR and the target solids concentration of 2 percent solids, rehabilitation of two GTs would provide sufficient process capacity. NEW Water may decide to rehabilitate all four GTs for redundancy purposes. The capital cost estimates for rehabilitation of two or four GTs is shown in Table 7-4.

Table 7-4 Capital Cost Estimates for Additional Package 1 and 2 Related to GT Rehabilitation

Package	Major Infrastructure	Potential Capital Cost Range	Most Probable Capital Cost
Additional Package 1	Rehabilitate two GTs, with associated pumping and piping	\$3.6M to \$5.3M	\$4.2M
Additional Package 2	Rehabilitate four GTs, with associated pumping and piping	\$7.1M to \$10.4M	\$8.4M

7.3.1.2 Thickened Wet Well and Pumping

An additional area for capital investment is the thickened sludge wet well and pumps. Currently, each thickening unit discharges into one of four wet wells. These wet wells are connected by pipes but are essentially independent. Progressive cavity pumps then pull sludge from the wet wells, but a series of bends exist between the wet well and the pump intake. This has led to stator wear due to grease clogging the inlet piping. Improvements to the wet well and new progressive cavity pumps were developed to improve the flowability and redundancy of the wet well system. Preliminary improvements identified include:

- Removing walls to create two thickened sludge wet wells
- Slopping the floor of the wet wells towards the pump suction
- Reorientation of the progressive cavity pump suction pipes

A preliminary layout of these wet well modification is shown in Figure 7-5. The capital cost estimates for the thickened sludge wet well and pumping improvements is shown in Table 7-5.




Figure 7-5 Conceptual Modification for Thickened Sludge Wet Well Modifications (Similar for Two Wells)

Table 7-5 Capital Cost Estimates for Thickened Sludge Wet Well and Pumping Improvements

Package	Major Infrastructure	Potential Capital Cost Range	Most Probable Capital Cost
Additional Package 3	Thickened wet well and pumping improvements	\$1.2M to \$1.8M	\$1.4M

7.3.1.3 Primary Sludge Directly to GBTs or RDTs

An alternative option for treating primary sludge is to send it directly to the GBTs or RDTs and not use gravity thickeners. Table 3-2 presented a summary of the PS design characteristics for the GBF. Based on the flows and loads shown, if the primary sludge was sent directly to the GBTs or RDTs an additional two or three thickeners would be required, in addition to the five to six presented in Section 7.1. Requiring a total of eight thickeners would necessitate an approximate 75 foot by 40 foot solids thickening building expansion to provide sufficient space for the new equipment. The expansion would require the relocation of existing piping, HVAC, and other infrastructure to complete. Installing the additional thickeners and expanding the building would cost at least an estimated \$5.0 M including engineering costs. This is greater than the approximate \$3.9 M required for Additional Package 1 presented in Table 7-4 for the rehabilitation of two GTs. In addition, there are operating advantages to utilizing the GTs. Due to costs and the operational advantages of continuing to operate the GTs this option was removed from further consideration.

7.3.1.4 Odor Control

If odor treatment was determined to be necessary for either infrastructure package, a total air flow of approximately 1,000 cfm, based on required air exchanges, would need to be treated. A carbon absorber on a 12 foot by 8 foot skid unit could treat flows at this rate, and would cost approximately \$200,000, including engineering to install.

7.4 Infrastructure Package summary

Five different infrastructure packages were developed for solids thickening management. Overall capital costs are summarized in Table 7-6. For the ultimate thickening solutions, NEW Water will need to choose Infrastructure Package 1 or 2, and combine with the desired additional infrastructure packages.

Table 7-6 Summary of Potential Infrastructure Packages

Infrastructure Package	Major Infrastructure	Potential Capital Cost Range	Most Probable Capital Cost
Package 1 Configuration 1a, 2a, 2a, 3b	<ul style="list-style-type: none"> • Five GBTs or RDTs • Required platforms and piping • Thickened sludge feed pumps • Odor mitigation 	\$5.7M to \$8.3M	\$6.7M
Package 2 All six configurations	<ul style="list-style-type: none"> • Six RDTs • Required platforms and piping • Thickened sludge feed pumps • Odor mitigation 	\$6.6M to \$9.7M	\$7.8M
Additional Package 1	<ul style="list-style-type: none"> • Rehabilitate two GTs, with associated pumping and piping 	\$3.6M to \$5.3M	\$4.2M
Additional Package 2	<ul style="list-style-type: none"> • Rehabilitate four GTs, with associated pumping and piping 	\$7.1M to \$10.4M	\$8.4M
Additional Package 3	<ul style="list-style-type: none"> • Thickened wet well and pumping improvements 	\$1.2M to \$1.8M	\$1.4M

8.0 Thickening Recommendations

Within the existing solids handling building, there is sufficient space for a six thickeners, but it would limit the technology solution to RDTs. This future flexibility is beneficial, but NEW Water does not have prior experience with the RDT technology. It would be beneficial to conduct a pilot test of the RDT technology in 2020 to gain operational exposure to the RDT. An applied research project to pilot test the RDTs with the different sludge streams at NEW Water would be valuable investment. Pilot equipment rental is \$40,000 to \$60,000 depending on the length of piloting (base price is for one month of pilot testing). Additional temporary piping, pumping, engineering support, and data analysis would bring the total pilot effort to a cost of \$75,000 to \$100,000. Pilot information is included in Appendix D.

The overall recommended package would include five thickeners, rehabilitation of four existing gravity thickeners, and modifications to the thickened sludge well and pumping. As shown in Table 8-1, this Total Thickening Infrastructure Package would have a capital cost range of \$14.1M to \$20.6M, with a most probable cost of \$16.6M.

Table 8-1 Recommended Thickening Infrastructure Package

Package	Major Infrastructure	Potential Capital Cost Range	Most Probable Capital Cost
Infrastructure Package 1	<ul style="list-style-type: none"> • Five GBTs or RDTs • Required platforms and piping • Thickened sludge feed pumps • Odor mitigation 	\$5.7M to \$8.3M	\$6.7M
Additional Package 2	Rehabilitate four GTs, with associated pumping and piping	\$7.1M to \$10.4M	\$8.4M
Additional Package 3	Thickened wet well and pumping improvements	\$1.2M to \$1.8M	\$1.4M
Applied Research: RDT pilot testing		\$75,000 to \$100,000	\$0.1M
Total Thickening Infrastructure Package		\$14.1M to \$20.6M	\$16.6M

As the Facility Plan advances, there are several related components to solids thickening that will need to be examined. Given the operational flexibility available with five thickening units, this would be a reliable initial investment in thickening for NEW Water. It also addresses the key drivers for thickening improvements:

- Industrial user growth at the GBF: increased overall thickening capacity.
- Aging equipment: existing mechanical thickeners will be replaced; the gravity thickeners will be rehabilitated.
- Operational limitations: a high degree of flexibility will be achieved for solids management.
- Growth in the DPF service area: increased overall thickening capacity.
- Resource Recovery and Energy Efficiency (R2E2) operation: reliable thickening of all sludge streams to 6 percent solids, as well as improvements to thickened sludge transfer.

- Nutrient harvesting: flexibility provided for future operation of nutrient harvesting facilities.

Several key areas that should be evaluated in more depth that relate to the thickening operation are:

- DPF operation: modifying the PTUs to have the solids flow mixed with WAS would benefit grit handling at the DPF, but the major impact is the reduced loading to the aeration basins at the DPF. This reduces the mixed liquor suspended solids at the DPF, which will lead to increased peak flow capacity. This impact will be quantified during the De Pere Facility Vision task.
- DPF grit management: the sizing and operation of the PTUs and the grit classifier may operate at a more constant flow rate than simulated; this would decrease the peak flow and load for design and potentially reduce the number of units required by one.
- Whole plant odor control: the current capital costs include odor mitigation inside the thickening building, with duct work and venting of the headspace around enclosed thickening devices. The need to treat this ventilated air will be evaluated as part of the Whole Plant Odor Control task.
- Selective wasting: as discussed, selective wasting does have an impact on the WAS solids concentration. The feasibility of selective wasting and process impacts will be evaluated as part of the Aeration and Nutrient Removal task.
- Nutrient harvesting: if five RDTs are installed as part of the thickening infrastructure package, there would be room for a sixth RDT in the future. This would provide the flexibility to operate in the previously developed configuration. However, if the soluble phosphorus concentration in the struvite harvesting is taken down to 20 mg/L, there is a minor benefit of the additional WAS thickening before P-release.

Appendix A. Solids Production Projections

Projected sludge flows and mass flow rates are summarized as box-and-whisker plots, where the bottom of the box is the 25th percentile, the middle line is the median (50th percentile) and the top of the box is the 75th percentile. Whiskers extend to the largest and smallest values that are not considered outliers. Outliers are values which are more extreme than the inner fences; inner fences are calculated by determining the range between the 25th and 75th percentiles (i.e., the interquartile range, IQR) and multiplying that by 1.5. The inner fences extend beyond the 25th and 75th percentiles by this calculated value. Boxes are colored according to the projected year being simulated. White dots are means of each data set.




Figure A-1 Boxplots of PS Flow Rates Assuming 2% Solids for Each Year as a Part of all Configuration Simulated. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-2 Boxplots of PS Flow Rates Assuming 3% Solids for Each Year as a Part of all Configuration Simulated. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-3 Boxplots of PS Mass Flow Rates for Each Year as a Part of all Configurations Simulated. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-4 Boxplots of Green Bay WAS flow rates for 8 scenarios as a part of all configurations simulated. Boxes are colored by 10-year dynamic input that was simulated. White points are means.




Figure A-5 Boxplots of Green Bay WAS mass flow rates for 8 scenarios as a part of all configurations simulated. Boxes are colored by 10-year dynamic input that was simulated. White points are means.




Figure A-6 Boxplots of De Pere WAS Mass Flow Rates for 4 Scenarios Simulated as a Part of Configurations 1a, 2a, and 3a. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-7 Boxplots of WAS Flow Rates for 4 Scenarios Simulated as a Part of Configurations 1b, 2b, and 3b. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-8 Boxplots of WAS Mass Flow Rates for 4 Scenarios Simulated as a Part of Configurations 1b, 2b, and 3b. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means.




Figure A-9 Boxplots of Combined WAS and PS Flow Rates for 8 Scenarios Simulated as a Part of Configuration 3a. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means




Figure A-10 Boxplots of Combined WAS and PS Mass Flow Rates for 8 Scenarios Simulated as a Part of Configuration 3a. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means




Figure A-11 Boxplots of Combined WAS and PS Flow Rates for 8 Scenarios Simulated as a Part of Configuration 3b. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Means




Figure A-12 Boxplots of Combined WAS and PS Mass Flow Rates for 8 Scenarios Simulated as a Part of Configuration 3b. Boxes are Colored by 10-Year Dynamic Input that was Simulated. White Points are Mean

Appendix B. Manufacturer's Proposal



ThickTech[™]

Rotary Drum Thickener

- Highest performance
- Lowest cost of ownership
- Adjustable to changing sludges
- Designed to build floc
- Sludges: waste activated, primary, blends, recuperative



Why Thicken Sludge?

- Increase digester capacity
- Reduce hauling costs
- Pre-thicken before other dewatering equipment

Sludge thickening, for example, can reduce 192,000 gallons of sludge per day down to 13,400 gallons by thickening 0.5% feed to 7%. The higher concentration of solids equates to more pounds of solids stored in the same volume area.

The industry leading Parkson ThickTech™ Rotary Drum Thickeners (RDT), with over 300 installations, consumes the lowest amount of expensive polymer while offering the highest capture rate of 98% and therefore, the lowest cost of re-treatment. Units are compact, require little operator attention and are pre-engineered for easy installation.



Why Rotary Drum Thickeners

- Fully enclosed – clean
- Odor control capability
- Smaller footprint
- Indoor/outdoor installation
- Ease of operation
- Low polymer usage
- Replace centrifuges
- Lower power costs
- Replace DAFs

Why Choose the Parkson ThickTech™

- Industry leading performance
- Quality of design
- Over 300 installations
- Designed to build floc
- Lowest polymer consumed
- Adjustable performance for changing sludges

Cost Savings Through Superior Design

A 400 GPM ThickTech™ RDT can save users ~\$860,000 or more in reduced polymer consumption over a 15-year period vs. a leading competitor. Savings are based on a side-by-side pilot test conducted by an independent third party.

Summary of Comparison Report (ThickTech vs. Leading Competitor)

	Parkson	Competitor
Inlet Sludge	400 GPM @ 0.95-1.37% Solids	400 GPM @ 0.95-1.37% Solids
Thickened Sludge	6.6%	6.6%
Polymer Use	72 lbs/day	168 lbs/day
Polymer Cost (@ \$2/lb)	\$52,458/year \$645,028/15 years*	\$122,402/year \$1,505,065/15 years*
\$860,037 savings		

* 3% net discount rate



Mobile on-site pilot testing

How the ThickTech Outperforms Other RDTs

Superior Drum Design Controls Sludge Advancement

Staged Screens:

- Dewatering occurs in four distinct dewatering stages divided by split augers
- Woven wire mesh size can be changed between stages to maximize dewatering

Roll Bars:

- Flip sludge over for additional water removal

Woven Wire Mesh Filtration Media:


- Provides significantly more open area than wedge wire or perforated plate
- Easily removable and replaceable to match sludge

Other Special Features:

- Perforated stainless steel support media
- Split augers
- Detention rings with ports to adjust sludge detention time
- Self-cleaning spray header with booster pump

Low Shear Flocculation Tank

Tangential Inlet and Outlet: All polymer mixing occurs prior to the sludge entering the flocculation tank. The tank is where the sludge and polymer grow into a popcorn floc before entering the drum. Tangential feed and outlets promise low shear and maximize floc size.



General Performance Specifications

Capacity	50 GPM – 400 GPM (50, 100, 150, 200, 300 and 400)
Inlet	0.5% - 1.5% solids
Outlet	5% - 8% solids
Typical Polymer Usage	5-10 lbs (100% active) / ton of sludge (dry wt.)
Solids Capture	98%+ for low retreatment costs

Polymer Cost by Dose


Polymer Use	Cost Over 10 Years	10-Year Difference from Base Case	
5 lbs/Dry-Ton	\$520,416	\$0	Parkson ThickTech™ Dose Range
10 lbs/Dry-Ton	\$1,040,832	\$520,416	
15 lbs/Dry-Ton	\$1,561,260	\$1,040,844	
20 lbs/Dry-Ton	\$2,081,680	\$1,561,264	Polymer Dose of Competitors
25 lbs/Dry-Ton	\$2,602,100	\$2,081,684	
30 lbs/Dry-Ton	\$3,122,520	\$2,602,104	
35 lbs/Dry-Ton	\$3,642,940	\$3,122,524	

* This table is based on 1,000 GPM @ 1.0% solids inlet sludge concentration

Screening Material


The ThickTech Way

Woven wire mesh with perpendicular openings has more open area and better water release for more efficient thickening.



The Competition


Perforated sheet and wedge wire drums have significantly less open area and lower solids capture. Multi-layered poly cloths can be hard to clean.



Flocculation Tank Design Builds a Popcorn Floc


The ThickTech Way

Tangential inlet and outlet openings maximize detention time and flocculation, reducing shear from turbulence.



The Competition


Direct inlet and outlets creates turbulence and fluid shear that break up and reduce floc development.



Internal Drum Components

The ThickTech Way

Internal drum components such as roll bars, split augers, flights and detention ports roll, flip and control sludge movement through the drum and detain sludge for maximum water release.



Fort Lauderdale
Chicago
Kansas City
Denver

1.888.PARKSON
technology@parkson.com
www.parkson.com





1401 West Cypress Creek Road
 Suite 100
 Fort Lauderdale FL 33309-1969
 Phone 1.888.PARKSON
 Fax 954.974.6182

ThickTech™ Rotary Drum Thickener (RDT) Budget

April 14, 2020

Black & Veatch
 Attn: Eric Redmond

Re: NEW Water Sludge Thickening

Parkson Corporation is pleased to provide a budget for our ThickTech™ rotary drum thickener (RDT) for your project. Your requested information is included with this letter, along with other items which detail our offering for this project.


Basis of Design	
Parameter	Values
Thickening Application	WAS, primary, or mix
Influent Flow	400 GPM maximum
Influent solids (%)	0.5%-1.5%
Capture Efficiency (%)	98%
Thickened Solids	6%
Polymer Usage	7 to 10 active lbs/dry ton sludge

The ThickTech RDT offers many advantages over other thickeners on the market. In addition to having the most installations (over 250 units), the longest history (over 20 years) and robust, high quality manufacturing made in America, the Parkson ThickTech™ uses less polymer than any other RDT on the market. For an RDT, more money is spent on polymer than for anything else in the system. Polymer costs more than electricity, supporting equipment, and can be up to 10 times the cost of the RDT itself! Although this is by far the highest cost item, it is regularly overlooked when selecting an RDT while focus is made on the comparative capital cost, which is a small fraction of the overall lifecycle costs.



Fort Lauderdale ♦ Chicago ♦ Montreal ♦ Dubai ♦ Mumbai

www.parkson.com
 technology@parkson.com



Calculation Basis:

Flow: 400 GPM @ 1.5% solids

Polymer cost: \$2.5/lb (active)

Operation: 5 days/week, 8 hrs/day

Discount Rate: 3%


As displayed in the 20 years Net Present Value (NPV) chart, the lifecycle polymer cost for given influent flow and solids could be as high as 2X for the competition. So, it is crucially important to pick the best performing unit for the lowest life cycle cost.

Why the Parkson ThickTech uses so less polymer is pretty elementary. It comes down to three things:

1. Flocculation tank design: The tangential inlet and outlet creates a swirling upward flow pattern with negligible shear promoting enhanced floc development.
2. Screening material: Woven wire mesh has the smallest opening size leading to high capture rates and most open area allowing for most efficient release of water.
3. Internal drum components: The drum is divided into four zones with split augers and detention ports to fine tune the sludge residence time and also prevents breaking down of floc. The roll bars allow for gentle flipping and turning of the sludge for efficient water removal.

So, although woven wire mesh screens can be a little more expensive up front, they save a lot of money down the line. Below is a picture of the Parkson drum showing the internal drum features compared to our two leading competitors (a wedge wire and perforated sheet drum).


Parkson Drum



Wedge Wire Drum



Perforated Sheet Drum



Scope:

- 304 SS unit
- Basic Controls
- End Enclosure
- Booster Pump
- Vortex Mixer with polymer injection ring

Based on the design parameters and above scope, the budget price for **one (1) RDT400** including startup service is.....**\$200,000 USD**

Thank you for considering the comments I have provided above. Should you have any questions at all I would appreciate the opportunity to discuss with you and provide answers.

Sincerely,

Dave Mitchell
RDT Product Manager

NUMBER: 09174

DATE: 03/27/20

TO: Black & Veatch
Attn : Leon Downing

REF.: Thickener

Budget Proposal
NEW Water
Green Bay, WI
THK 600 Thickening Unit



Centrisys Contact

Josh Gable
Regional Sales Manager
9586 58th place
Kenosha, WI 53144
Ph: (262) 654-6006
Direct: (262) 705-3064
Email: josh.gable@centrisys.us


Centrisys Representative

Rachel M. Lee, P.E.
LAI, Ltd.
2935 S. Fish Hatchery Rd. #116
Madison, WI 53711
Office: (608) 298-7271
Cell: (608) 698-6531
Email: rlee@lai-ltd.com

Process Description: Centrisys THK Series

The THK Thickening Centrifuge:

Sludge thickening using centrifugal force is a common process that can be applied to increase the concentration of sludge for further processing. During operation, sludge is continuously fed into the unit. The moving shaft has a set of helical scrolls, which push the solid waste towards one end, away from the liquid moving in the opposite direction. Centrisys' innovative, patented Hydraulic Assist Technology discharges the thickened sludge more efficiently while reducing costs. Our centrifugal thickening process is the smallest footprint approach to reduce volume while increasing digesting capacity and performance.



The most significant differentiator of the Centrisys THK product is its ability to achieve 2 -6% cake solids **without the use of polymer**. Within this range, the solids content can be reliably controlled at the desired level. We've validated these results in pilots and demonstration installations across the United States for waste active sludge. This is a huge benefit to water & wastewater treatment facilities by substantially reducing their operating costs. Compared to gravity belt thickeners, a comparable Centrisys THK unit thickener has demonstrated a potential payback of 5 years, or less, based on reductions in polymer, water & electricity usage. We've recorded similar results compared to DAF thickening systems, while using a fraction of the required footprint.

The Centrisys THK Series Design

Centrisys considers all critical design elements including axial flow, pitch design, scroll hub design, cone angles, feed chamber design and disc design, hydra-pneumatic control of the cake solids, Rotor aerodynamics, discharge nozzle geometry, plus our advanced high torque hydraulic Centrisys scroll-drive to achieve the highest performance of any decanter centrifuge. The bowl section is maximized in length (varying from 3.5 to 4.5, depending on the size) for high flow rate and efficient clarification.

Feed Flow

The Centrisys advanced feed chamber design minimizes wear and maximizes performance. This design gently accelerates the continuous incoming feed and distributes it evenly over a larger area as it enters the bowl through multiple field-replaceable tungsten carbide nozzles. This maximizes separation and clarification while minimizing wear, and avoids disturbing already-separated cake solids in the liquid layer.

Patented Hydro-Pneumatic Solids Control

Using injection of air into the thickened solids blanket, coupled with the already present centrifugal force, adjustment of the cake solids consistency can be made on the fly.

- If a plant operator desires to modify the cake solids consistency, the airflow of the THK thickener can be adjusted via the HMI, quickly changing output solids consistency on-demand, without any mechanical adjustments or shutting down the unit.

Polymer Feed Injection Option

The proprietary internal polymer injection design provides the option to inject polymer directly into the fast moving layer of water which flows axially along the hub towards the liquids end of the bowl. Generally, for WAS we do not foresee the necessity for polymer use under normal circumstances. However, use of polymer can be used to substantially increase throughput of the THK (typically by 75 to 100%) while maintaining high solids capture efficiencies. Because of the internal polymer injection design, polymer doses are typically 10 to 20% of other mechanical thickening technologies, even at maximum capacities.

Low Speed Operation

The THK series centrifuge is designed to for operation up to 3,000 G – standard for decanting centrifuges. However, because the separation and discharge mechanisms for the THK units are so much different than for conventional centrifuges, the typical bowl speeds required are much lower – typically within the 1,000 to 2,000 G range. This means less power is consumed and the machine's wear is much less than what is typically observed in modern decanter centrifuges.

Centrisys is pleased to provide this quotation for the following:

ONE (1) THICKENING CENTRIFUGE UNIT, MODEL THK 600 COMPLETE WITH AUTOMATIC HYDRAULIC BACKDRIVE

ITEM 1. BASIS OF DESIGN

Industry Type:	Municipal	
Application:	WAS & Primary/WAS Co-Thickening	
Number of units:	1,2, or 3	
Design Hydraulic Throughput/Unit –		
WAS thickening:	278 – 921	gpm
Co-thickening:	576 – 921	gpm
Design Solids Loading Rate/Unit –		
WAS thickening:	698 – 2485	lb/hr
Co-thickening:	1764 – 4217	lb/hr
Feed Concentration:		
WAS thickening:	0.23 – 0.83	%TS
Co-thickening:	0.47 – 1.3	%TS
Organic/Volatile Content:	TBA	%VS
Operation time:	24	hrs/day; 7 days/week
Temperature:	Ambient	
pH:	6-8	

ITEM 2. ANTICIPATED PERFORMANCE

See spreadsheet

ITEM 3. CENTRIFUGE SPECIFICATION

Model:	THK 600	
Inside bowl diameter:	26	in
Bowl length:	118	in
Bowl length to diameter ratio:	4.5:1	
Maximum Bowl speed:	2850	rpm
Type of lubrication:	Air/Oil	
Main Motor Size:	150	HP
Back Drive Motor Size:	25	HP
Max Hydraulic Throughput:	1100	gpm

ITEM 4. SCOPE OF SUPPLY

Each unit will be provided based on the attached drawing THK 600 GA.pdf

- (i) Centrifugally Casted Duplex SS Solid bowl
- (ii) Scroll conveyor with Duplex SS Scroll shaft; 316SS flights
- (iii) 316 SS lower and upper casing
- (iv) Solid and liquid flexible connectors
- (v) Dewatered Sludge and Centrate Chutes/Hoppers
- (vi) Powder coated carbon steel base/frame
- (vii) Vibration isolators
- (viii) Spare parts/tools
- (ix) Control Panel (water cooled)
 - A. 304SS NEMA 4X Enclosure for each centrifuge
 - B. Main circuit breaker
 - C. VFD for main drive motor
 - D. Allen Bradley PLC (compact logix), valve amplifier and motor starter for automatic hydraulic back drive system
 - E. Ethernet communication and historical trending of key parameters
 - F. 10" Allen-Bradley panel view touch screen
- (x) Instrumentation
 - A. One (1) vibration sensor per unit
 - B. One (1) main bearing temperature sensor, type PT100 on each bearing
 - C. One (1) each Bowl/Scroll speed sensor/unit
 - D. One (1) Hydraulic oil level/temp, hydraulic pressure sensor/unit
- (xi) Automatic Air/Oil Lubrication System
 - A. One (1) low air/oil level sensor per unit
- (xii) One (1) trip and 5 days of startup assistance

ITEM 5. BUDGET PRICE

All of the above for **\$638,900** USD
 F.O.B. Job Site, freight included, taxes excluded.

PAYMENT TERMS:

30% with order; 60% upon shipment; 10% after startup not to exceed 90 days after shipment.

ITEM 6. LEAD TIME

18-20 weeks following receipt of the Approval drawings

ITEM 7. BUYER/OWNER RESPONSIBILITY



- Stand
- Feed pump
- Polymer system
- Flow meter
- Air compressor
- Cake conveyor
- Anchor bolts.

- Building and building plans (Centrisys provides only the layout drawings without any responsibility of updating any plans or building)
- Building modifications
- Structural and Civil engineering labor
- Lubricants
- All utilities that are required for operation
- Unloading, uncrating, installation and installation supervision. Installation will, at minimum, require a forklift and possibly a crane/hoist.
- Readiness of the Equipment before requesting start-up service. Non-readiness may incur additional charges.
- Compatibility of Equipment materials of construction with process environment.
- Piping connections, platforms, gratings and railings unless stated otherwise.
- Any other auxiliary equipment or service not detailed above.

Issued by:







Brett Bevers
Applications Engineer

Date:03/27/20



Est. Centrifuge Loading:	lbs [kg]
Rotating Assembly	9150 [4150]
Bowl Filling w/SP 1.0	2000 [907]
Complete Centrifuge (w/o filling)	27000 [12247]
Static loads below foot pads:	
A	3821 [1733]
B	3821 [1733]
C	3821 [1733]
D	3821 [1733]
E	2929 [1329]
F	2929 [1329]
G	2929 [1329]
H	2929 [1329]
Dynamic loads below each corner of complete centrifuge:	
A	4203 [1906]
B	4203 [1906]
C	4203 [1906]
D	4203 [1906]
E	3222 [1461]
F	3222 [1461]
G	3222 [1461]
H	3222 [1461]
Dynamic loads below each corner of complete centrifuge with full bowl @ start-up during critical:	
A	4575 [2075]
B	4575 [2075]
C	4575 [2075]
D	4575 [2075]
E	3400 [1542]
F	3400 [1542]
G	3400 [1542]
H	3400 [1542]

*Assume horizontal loads approximately 5% of vertical loads



		9586 58th Place Kenosha, WI 53144 Tel: (262) 654-6006 Fax: (262) 764-8705		THIS PRINT IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF CENTRISYS. Title: THK 26-600 General Arrangement	
Designed by: A.A.	Date: ---	G&T ASME Y14.5M1994+ Tolerancing Std. & Rules apply	3rd Angle Projection	See BOM	Sheet Size: D
Drawn by: A.A.	Date: 8/26/13	Estimated weight (lbs): ---	See Note	Drawing #: GA23210	Scale: 1:24
Approved by: ---	Date: ---	Project:	Sheet: 1 OF 3	Scale: 1:24	REV



Budgetary Sizing for Black & Veatch New Water, Green Bay, WI Facility Plan

ANDRITZ Rotary Drum Thickener
ANDRITZ Gravity Belt Thickener

Bid Scope No: 3314745
Date: 3/30/2020

By: Chris Mahoney
Tel: (817) 271-4826
Email: chris.mahoney@andritz.com



ENGINEERED SUCCESS

ANDRITZ Separation Technologies Inc.
1010 Commercial Blvd. South
Arlington, TX 76001
(817) 465-5611
Separation.us@andritz.com
www.Andritz.com





3/30/2020

Leon S. Downing, Ph.D., P.E

Black & Veatch
826 Minakwa Dr
Madison, WI 53711

Reference: **New Water, Green Bay, WI
Facility Plan**

Subject: **ANDRITZ Budgetary Proposal 3314745**

Thank you for the opportunity to provide this preliminary equipment sizing and budgetary pricing for use in your study for New Water project.

We understand that the process data is still being developed and may not completely balance out at this point. Where we found potential conflicts we either adjusted it or based our sizing on the hydraulic loadings since they are normally more of a firm estimate at this point in a study.

While a number of models and sizes of equipment can be reviewed at the time of final analysis to provide the best cost and performance, for this review the primary equipment used for this analysis is the following.

Rotary Drum Thickeners –

Thicken WAS and Primary sludges from 0.5%-5% (higher with primary blends)

Model PDR 900XL – Capacities up to 250 GPM

Budgetary Costs - \$175,000 USD per machine

Model PDR 1200 - Capacities up to 420 GPM

Budgetary Costs - \$205,000 USD per machine

Gravity Belt Thickeners

ANDRITZ 1 Meter GBT – Primary and secondary sludges up to 300 GPM

Budgetary Costs - \$200,000 USD per machine

ANDRITZ 2 Meter GBT – Primary and secondary sludges up to 300 GPM

Budgetary Costs - \$225,000 USD per machine

ANDRITZ 3 Meter GBT – Primary and secondary sludges up to 300 GPM

Budgetary Costs - \$400,000 USD per machine

Data Sheets and typical engineering drawings are included for your use.

Case 1:

WAS THICKENING INFORMATION

- Requested technologies:
- Rotary Drum Thickener
- Gravity Belt Thickener

Table 1. WAS flow rates and concentrations for each of five loading scenarios and at four different percentiles

Equipment sizing										
Process Conditions										
	Flow [gpm]					Mass Load [ppd]				
	WT1	WT2	WT3	WT4	WT5	WT1	WT2	WT3	WT4	WT5
2025 25th	576	1,106	278	833	279	50,881	55,745	27,630	26,500	21,458
2025 50th	736	1,474	434	1,052	298	56,077	62,223	31,471	30,900	24,277
2040 50th	921	1,689	585	1,119	298	59,636	66,329	32,835	33,480	26,574
2040 90th	1,157	2,235	700	1,638	536	72,235	80,472	38,865	44,739	36,712
Rotary Drum Thickeners										
	Flow [gpm]					Mass Load [ppd]				
	WT1	WT2	WT3	WT4	WT5	WT1	WT2	WT3	WT4	WT5
2025 25th	2x PDR1200	3x PDR1200	1x PDR900XL	2x PDR1200	1x PDR1200	50,881	55,745	27,630	26,500	21,458
2025 50th	2x PDR1200	4x PDR1200	2x PDR900XL	2x PDR1200	1x PDR1200	56,077	62,223	31,471	30,900	24,277
2040 50th	3x PDR1200	4x PDR1200	2x PDR1200	2x PDR1200	1x PDR1200	59,636	66,329	32,835	33,480	26,574
2040 90th	3x PDR1200	4x PDR1200	2x PDR1200	3x PDR1200	2x PDR1200	72,235	80,472	38,865	44,739	36,712
Gravity Belt Thickeners										
	Flow [gpm]					Mass Load [ppd]				
	WT1	WT2	WT3	WT4	WT5	WT1	WT2	WT3	WT4	WT5
2025 25th	1x 3M GBT	2x 3M GBT	1x 2M GBT	2x 2M GBT	1x 2M GBT	50,881	55,745	27,630	26,500	21,458
2025 50th	1x 3M GBT	2x 3M GBT	1x 2M GBT	2x 3M GBT	1x 2M GBT	56,077	62,223	31,471	30,900	24,277
2040 50th	2x 2M GBT	3x 3M GBT	1x 3M GBT	2x 3M GBT	1x 2M GBT	59,636	66,329	32,835	33,480	26,574
2040 90th	2x 3M GBT	3x 3M GBT	1x 3M GBT	3x 3M GBT	2x 2M GBT	72,235	80,472	38,865	44,739	36,712

Case 2:

PS THICKENING INFORMATION

- Requested technologies:

Table #2	GBT Sizing Only			
	Flow [gpm]	Corrected Flow [gpm] for 2% solids	Mass Load [ppd]	Equipment
2025 25 th	0.14	146	35,083	1x 1M GBT
2025 50 th	0.2	163	39,121	1x 1M GBT
2040 50 th	0.24	170	40,862	1x 1M GBT
2040 90 th	0.31	216	51,809	1x 1M GBT
ANDRITZ 1.0 meter GBT has a capacity of 300 GPM on				

Case #3

COMBINED WAS AND PS THICKENING INFORMATION

Table 3. Combined flow rates and concentrations for two loading scenarios at four different percentiles.

- **Requested technologies:**
- Rotary Drum Thickener
- Gravity Belt Thickener

	Flow [gpm]		Mass Load [ppd]	
	Co-T1	Co-T2	Co-T1	Co-T2
2025 25 th	576	1,106	88,355	92,985
2025 50 th	736	1,475	95,701	101,503
2040 50 th	921	1,690	101,213	107,271
2040 90 th	1,157	2,235	120,005	126,995
Rotary Drum Thickener				
	Flow [gpm]		Mass Load [ppd]	
	Co-T1	Co-T2	Co-T1	Co-T2
2025 25 th	2x PDR1200	3x PDR1200	88,355	92,985
2025 50 th	2x PDR1200	4x PDR1200	95,701	101,503
2040 50 th	3x PDR1200	4x PDR1200	101,213	107,271
2040 90 th	3x PDR1200	4x PDR1200	120,005	126,995
Gravity Belt Thickener				
	Flow [gpm]		Mass Load [ppd]	
	Co-T1	Co-T2	Co-T1	Co-T2
2025 25 th	1x 3M GBT	2x 3M GBT	88,355	92,985
2025 50 th	1x 3M GBT	2x 2M GBT	95,701	101,503
2040 50 th	2x 2M GBT	3x 3M GBT	101,213	107,271
2040 90 th	2x 3M GBT	3x 3M GBT	120,005	126,995

Please use the sizing tables above in conjunction with the budgetary numbers to generate the preliminary capital costs for the recommended equipment. In addition, we have made some assumptions on the number and size of the units. If you feel that you need redundancy in the case of one machine specified and you want to move down to two machines of a smaller size, the information above should help you make that adjustment.

O&M Costs

All of this equipment uses small motors, 5-10 hp so the major costs associated with operations is polymer usage which is driven by the solids end of the equation. For preliminary estimates you can use 5-10 lbs/ton (active).

I hope this provides you with the information you need and please feel to call or email me directly if you have any questions.

Included in this document is ANDRITZ Proposal for the above referenced equipment specification section. ANDRITZ is bidding as a named Rotary Drum Thickener supplier with our ANDRITZ PDR-900XL Sludge Thickener.

ANDRITZ is a world leader in liquids/solids separation and drying equipment. We have earned a reputation for engineering and manufacturing equipment of the highest quality. We trust that our quality service and value will enable ANDRITZ to be the Rotary Drum Thickener supplier for this project.

Your consideration is appreciated.

Sincerely,

Chris Mahoney

Chris Mahoney
Regional Sales Manager
ANDRITZ Separation Technologies, Inc.
Cell: (817) 271-4826
Email: chris.mahoney@andritz.com
www.ANDRITZ.com

DRUM THICKENER

PDR 900



General

The PDR Series drum thickeners ensure dynamic thickening by continuous rotation of sludge for large flow (35 to 90 m³/hr)

Dynamic mechanical thickening allows a compact and completely enclosed solution. The specific installation with inline Venturi mixer optimizes compactness of system and decreases polymer consumption.

Dimensions and Weight

See table1

Construction Materials

Frame tank	1.4306 (AISI 304L)
Drum	1.4306 (AISI 304L)
Belt	Polyester
Spray ramp	1.4306 (AISI 304L)
Nozzle	PVDF
Cover	1.4306 (AISI 304L)
Frame finishing	Acid pickling
Cover finishing	Brushed Stainless Steel
Option:	
Raw Material	1.4404 (AISI 316L)

Frame

Thickness	3mm
-----------	-----

Drum

Diameter	900 mm
Length	2370, 3370, 4370 mm
Speed	2.80 to 8.30 RPM

Belt

Size	2830 x 1000mm
Type	Linear Screen
Quantity:	
M	1
L	1
XL	2
Type	Spiral dry
Quantity:	
M	1
L	2
XL	2

Washing spray pipe

Flow	See Table 1
Pressure	8 bar
Quality	500µm (100ppm) Without Sulfite or/and Chloride

Air Connection (suction)

Flow :	
M	30 m ³ /h
L	45 m ³ /h
XL	55 m ³ /h

Gear-motor & frequency inverter

See table 2

Lubrication

Bearing	with grease/ type: KP2K
Gear motor	Oil (CLP220 Mineral)

Noise level

Noise	< 80 dB(A)
-------	------------

Inline Dynamic Venturi Mixer

See table 3

Raw Material	1.4404 (AISI 316L)
--------------	--------------------

DRUM THICKENER

PDR 900




Dimensional

Type M

Type L

Type XL



		M	L	XL
Length	mm	2978	3948	4948
Height	mm	1733		
Width	mm	1179		
Empty weight	kg	645	779	916
Load weight	kg	761	940	1122
Maintenance footprint	drawing number	54047 (M)	54047 (L)	54047 (XL)
Anchors (option)	Anchor Bolts	x4 - M12 /A4-70	x4 - M12 /A4-70	x4 - M12 /A4-70
Flow supply (8 bar)	m3/h	4	6	8
Power	Kw	1,1	1,5	1,5

Table 1

Moto-reducer & frequency inverters


		M	L – XL
Moto-reducer			
Type		Helical Bevel gear	
Power	kW	1.1	1.5
Voltage	V	230/400	230/400
Rated current	A	4 / 3,1	7 / 4
Frequency	Hz	50	
Output speed	RPM	2.80 to 8,30	
Service factor		1,2	0,9
Hollow shaft	Ø	50mm	
Motor protection type	IP	54	55
Thermal Classification		B	
Efficiency Class		IE2	
Performance (50 / 75 / 100% Pn)	%	77,2 / 79,4 / 78,7	79,7 / 81,5 / 80,9
Weight	Kg	76	80.538
Option		Explosion proof	
Frequency inverters			
Nominal voltage	V	380...500	
Power Motor at 400V (low overload)	KW	1.1	1.5
input Frequency	Hz	50...60 (+/-10%)	
Protection	IP	21	

Table 2



DRUM THICKENER

PDR 900

Connection



ITEM	DESCRIPTION	DIMENSIONS	DETAILS
A	Sludge Inlet	DN 150 (ISO)	Flange
B	Filtrate outlet	DN 200 (ISO)	Flange
C	Sludge outlet	200mm x 200mm ext.	Square Flange
D	Wash water Inlet (Drum)	Ø1" G Male	Flange
E	Air connection (suction)	Ø114.3mm Ext	Flange
F	Sludge Inlet drain	Ø2" G Male	Threaded + cap
G	Wash water Inlet (Tank)	Ø1" G Male	Threaded
H	Filtrate sample	Ø1" G female	Manuel valve



DRUM THICKENER


PDR 900



Options



Hydraulic piping preparation:

- X2 Solenoid valve
- X1 Pressure switch
- X1 Manual valve



Sludge outlet interface:


- Rubber skirt [1]
- Bellows [2]



DRUM THICKENER

PDR 900

Inline Dynamic Venturi Mixer



TYPE	Flow Min. m3/h	Flow Max. m3/h	Dimensions (L/w/h)	Connection	Polymer connection	Weight (kg)
4" VENTURI	4,5	23	500x450x500	ISO DN100 PN10	G1" Female threaded	20
6" VENTURI	23	91	560x450x500	ISO DN150 PN10	G1" Female threaded	25
10" VENTURI	91	275	560x450x500	ISO DN250 PN10	G1" Female threaded	40

Table 3

* Head loss: 0,5 to 1 bar.

** The Venturi Mixer needs to be located 5 meters away from headbox or closer but the efficiency will be lowered. Two locations must be considered on the pipe (5 and 10 meters away) according to sludge and polymer rate.

DRUM THICKENER

PDR 1200



General

The PDR 1200 Series drum thickeners ensure dynamic thickening by continuous rotation of sludge for very large flow (up to 140 m³/hr)

Dynamic mechanical thickening allows a compact and completely enclosed solution. The specific installation with inline Venturi mixer optimizes compactness of system and decreases polymer consumption.

Dimensions and Weight

See table 1

Construction Materials

Frame tank	1.4306 (AISI 304L)
Drum	1.4306 (AISI 304L)
Belt	Polyester
Spray ramp	1.4306 (AISI 304L)
Nozzle	1.4404 (AISI 316L)
Cover	1.4306 (AISI 304L)
Frame finishing	Acid pickling
Cover finishing	Brushed Stainless Steel
<u>Option:</u>	
Raw Material	1.4404 (AISI 316L)

Frame

Thickness main body	5 mm
Thickness tank	3 mm

Drum

Diameter	1200 mm
Length	4430 mm
Speed	1.8 to 8.4 RPM

Belt

Size	3800 x 1000 mm
Linear screen:	2
Spiral dry:	2

Washing spray pipe

Flow	13.2 m ³ /h
Pressure	8 bar
Quality	500µm (100ppm)

Without Sulfite or/and Chloride

Air Connection (suction)

Flow : 110 m³/h

Gear-motor & frequency inverter

See table 2

Lubrication

Bearing with grease/ type: KP2K
Gear motor Oil (CLP220 Mineral)

Noise level

Noise < 80 dB(A)

Inline Dynamic Venturi Mixer

See table 3


Raw Material 1.4404 (AISI 316L)

DRUM THICKENER

PDR 1200



Dimensional



		PDR 1200
Length	mm	5663
Height	mm	2125
Width	mm	1650
Empty weight	kg	2260
Load weight	kg	2950
Maintenance footprint	drawing number	702906657
Anchors (option)	Anchor Bolts	x4 – M16 /A4-70
Flow supply (8 bar)	m ³ /h	13.2
Power	Kw	1,5

Table 1

Gearmotor & frequency inverters


Gearmotor			
Type		Helical Bevel gear	
Power	kW	1.5	1.5
Voltage	V	230/400	230/460
Rated current	A	3.23	2.8
Frequency	Hz	50	60
Output speed	RPM	2.80 to 8,30	2.80 to 8,30
Service factor		1,2	1.4
Hollow shaft	∅	60mm	60mm
Motor protection type	IP	55	55
Thermal Classification		B	B
Efficiency Class		IE3	Premium
Performance	%	85.3	
Weight	Kg	133	133
Option		Explosion proof	Explosion proof
Frequency inverters			
Nominal voltage	V	380...500	
Power Motor at 400V (low overload)	KW	1.5	
input Frequency	Hz	50...60 (+/-10%)	
Protection	IP	21	

Table 2

DRUM THICKENER

PDR 1200

Connection



ITEM	DESCRIPTION	DIMENSIONS	DETAILS
A	Sludge Inlet	DN 250 (ISO)*	Flange
B	Filtrate outlet	DN 300 (ISO)*	Flange
C	Sludge outlet	300mm x 310mm ext.	Square Flange
D	Wash water Inlet (Drum)	Ø2" G Male	Threaded
E	Air connection (suction)	Ø168.3mm Ext	Flange
F	Sludge Inlet drain	Ø2" G Male	Threaded + cap
G	Wash water Inlet (Tank)	Ø1" G Male	Threaded
H	Filtrate sample	Ø1" G female	Manuel valve

*Option: Flange ANSI

DRUM THICKENER


PDR 1200




Options

Hydraulic piping preparation:

- X2 Solenoid valve
- X1 Pressure switch
- X1 Manual valve



Inline Dynamic Venturi Mixer





TYPE	Flow Min. m3/h	Flow Max. m3/h	Dimensions (L/w/h)	Connection	Polymer connection	Weight (kg)
10" VENTURI	91	275	560x450x500	ISO DN250 PN10	G1" Female threaded	40


Table 3

* Head loss: 0,5 to 1 bar.


** The Venturi Mixer needs to be located 5 meters away from headbox or closer but the efficiency will be lowered. Two locations must be considered on the pipe (5 and 10 meters away) according to sludge and polymer rate.




View A
(1 : 8)



Without cover / Sans couverture
(1 : 10)



MASSÉ / MASS (kg)	Description	Value
	Capot + rampe de lavage / Cover + washing ramp	232
	Tambour + moteur / Drum + motor	387
	Cuve / Tank	416
	Masse totale version standard / Total mass in standard version	936
	Masse totale en tout options / Total mass in full options	946



Ø (mm)	Tightening torque / Couple de serrage (N*m)
M4	2
M6	7
M8	13
M12	57
M16	140

Method	Form	Surface texture	Welding	Finishing	Reference
ISO 2768 mK-E	ISO 2768 k-E	ISO 9013-341	ISO 15020-BAE	ISO 80623-3	Dict 10

SAP Material / Item name	AMC	Basic material name	Basic material standard
202819640	1050 00 01 000	1.4306	EN10028-7
202819539	1000 00 01 000	1.4404	EN10028-7



DRUM THICKENER

TAMBOUR EGOUTTEUR





702712905

ANRITZ

Status: Released



For machine lifting (and transportation), access door located upper this lifting eye has to be removed
/ Pour le levage de la machine (et son transport), la trappe d'accès située au dessus de cet anneau de levage doit être déposée.



NON VALABLE POUR EXECUTION
NOT VALID FOR EXECUTION

NOTE:
- For all machine installed on a base upper than 600mm, a platform with guiderail has to be installed for operations and machine maintenance
- Necessary height to dismount the drum of the tank (without slinging) : 2700mm
- Thickened sludge collector has to avoid any operator access in the operating machine
- Anchor bolts on floor are not delivered with machine
- Transportation package dimensional : 2130 x 5670 x 1650

NOTA:
- Pour tout appareil installé sur un support supérieur à 600mm, une plateforme avec garde corps devra être installé pour l'exploitation et la maintenance de la machine
- Hauteur nécessaire pour démontage du tambour de la cuve (sans élingage) : 2700mm
- Le collecteur de boue épaissie doit empêcher tout accès à l'intérieur de la machine en fonctionnement pour l'opérateur
- Les vis de fixation dans le sol ne sont pas fournies avec la machine
- Dimension pour transport : 2130 x 5670 x 1650

Masse / Mass (kg)	Capot + rampe de lavage / Cover + washing ramp	510
	Tambour + moteur / Drum + motor	895
	Cuve / Tank	930
	Masse totale version standard / Total mass in standard version	2330
	Masse totale en toutes options / Total mass in full options	2360
	Masse maxi en charge / Max operating mass	3050

A	Alimentation boues	Sludges feeding	DN 250
B	Alimentation eau de lavage tambour	Inlet water for drum cleaning	IS07 R2*
C	Désodorisation	Deodorization	Ø168.3
D	Sortie filtrats	Filtrate outlet	DN 300
E	Vidange boîte alimentation	Inlet box drain	IS07 R2*
F	Prise échantillon filtrats	Filtrate sampling	IS07 R1*
G	Alimentation eau lavage cuve	Inlet water for tank cleaning	IS07 R1*
H	Sortie boue	Sludge sampling	300 x 310
I	Prise échantillon boue	Sludge filtrate	Ø33,7
J	Option hydraulique	Hydraulic option	IS07 R2*
	Alimentation eau de lavage tambour + cuve	Inlet water for drum and tank cleaning	IS07 R2*

PDR 1200

702906657 C





PDR 1200

TAMBOUR EGOUTTEUR
PDR 1200

ANRITZ

Status: Released

- NOTE:**
1. THE FOUNDATION DESIGN INDICATES MINIMUM REQUIREMENTS FOR CLEARANCE AND DRAINAGE. ACTUAL FOUNDATION DESIGN AND CONSTRUCTION TO BE FURNISHED BY OTHER THAN ANDRITZ.
 2. MACHINE MUST BE LEVLED TO WITHIN 1/16 INCH.
 3. SUPPORTS BY OTHER THAN ANDRITZ.
 4. ALL DIMENSIONS ARE PRELIMINARY.
 5. MINIMUM LIMITS REQUIRED:
 - 5.1. ELECTRIC MOTOR: 5 HP - 480V/29H/60HZ
 - 5.2. WASH WATER - 69 GAL/MIN AT AMBIENT TEMPERATURE AND 120 PSIG
 - 5.3. AIR: 4 CFM AT 100 PSIG
 - 5.4. DRY WEIGHT OF THE MACHINE: 6240 kg [13,761 LBS]
 - 5.5. WET WEIGHT OF THE MACHINE: 6377 kg [14,100 LBS]



END ELEVATION


SIDE ELEVATION

THIS DRAWING IS A PART OF THE CONTRACT DOCUMENTS FOR THE PROJECT. IT IS THE PROPERTY OF ANDRITZ. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. ANY UNAUTHORIZED USE OF THIS DRAWING IS PROHIBITED. THE USER OF THIS DRAWING SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE APPROPRIATE AUTHORITIES. ANDRITZ SHALL NOT BE RESPONSIBLE FOR ANY DAMAGE TO PERSONS OR PROPERTY ARISING FROM THE USE OF THIS DRAWING.

ESTIMATED WEIGHT IN LBS.	—
UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES AND DECIMALS THEREOF.	
DATE	12/14/18
CHECKED BY:	OC
DATE	12/14/18
APPROVED BY:	OC
DATE	12/14/18
PROJECT LOCATION:	ANDRITZ CORPORATION, INC. 1010 COMMERCIAL BLVD., SUITE 100 ARLINGTON, TEXAS 76011 PHONE: (817) 461-9611

TITLE	3.0m GBT
GENERAL ARRANGEMENT	
GBT FOUNDATION DETAILS	
SCALE	1/16
DATE	DMF1514
SHEET	1

- 1.0 FRAME ASSEMBLY
- 2.0 ROLL ASSEMBLY
- 2.1 DRIVE ROLL ASSEMBLY
- 2.2 DEFLECTING ROLL ASSEMBLY
- 3.0 BELT TENSION ASSEMBLY
- 4.0 TRACKING ASSEMBLY
- 5.0 FILTRATE PAN ASSEMBLY
- 5.1 BELT ACCESS PANELS
- 6.0 SHOWER ASSEMBLY
- 6.1 SHOWER WATER INLET, 2" FNPT
- 6.2 SHOWER WATER DRAIN CONNECTION, BOTH SIDES, 2" MNPT
- 7.0 BELT DOCTOR ASSEMBLY
- 8.0 HEADBOX ASSEMBLY
- 8.1 RETENTION TANK DRAIN, BOTH SIDES, 2" MNPT
- 8.3 ODOR CONTROL HOOD
- 10.0 GRID ASSEMBLY (NOT SHOWN)
- 13.0 DRIVE ASSEMBLY
- 15.0 PLOW ASSEMBLY (NOT SHOWN)
- 20.0 FILTRATE DRAIN (BOTH SIDES)
- 21.0 SHOWER INLET PIPING, DRIVE SIDE
- 23.0 PNEUMATIC COMPONENTS
- 23.1 PNEUMATIC CONTROL CONSOLE
- 23.2 INLET AIR CONNECTION
- 25.0 VENTURI MIXER ASSEMBLY
- 40.0 BELT



NOTES:

1. FINAL ROUTING OF SLUDGE FEED PIPING BY OTHERS. SLUDGE FEED PIPING IS TO BE SUPPORTED BY OTHERS. FLEXIBLE CONNECTION MUST BE INSTALLED TO ISOLATE MACHINE FROM PIPING MOVEMENT. SLUDGE FEED PIPING AND FLEXIBLE CONNECTION TO BE SUPPLIED BY OTHERS.
2. VENTURI MIXER SHOULD BE LOCATED APPROXIMATELY 15 FEET FROM THE INLET FLANGE. PROVISIONS SHOULD BE MADE FOR ALTERNATE DISTANCES OF 30 FEET AND 45 FEET.
3. FOUNDATION DETAILS SHOWN ON DRAWING DMF-1514.
4. RH MACHINE AS SHOWN. LH OPPOSITE AS SHOWN.

THIS DRAWING IS A REVISION TO THE ORIGINAL DRAWING. ANY CHANGES TO THE ORIGINAL DRAWING MUST BE MADE BY THE ORIGINAL DESIGNER OR HIS AUTHORIZED REPRESENTATIVE. ANY ALTERATION OF THIS DRAWING FOR ANY OTHER PROJECT WITHOUT THE WRITTEN CONSENT OF ANDRITZ SEPARATION, INC. IS PROHIBITED. THIS DRAWING IS THE PROPERTY OF ANDRITZ SEPARATION, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF ANDRITZ SEPARATION, INC. THIS DRAWING IS THE PROPERTY OF ANDRITZ SEPARATION, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF ANDRITZ SEPARATION, INC.

ESTIMATED WEIGHT IN LBS:	—
DRAWN BY:	QC
CHECKED BY:	7/8
APPROVED BY:	7/8
DATE:	12/14/18
DATE:	12/14/18
THIRD ANGLE PRODUCTION	


ANDRITZ
 ANDRITZ SEPARATION, INC.
 10100 ARLINGTON, TEXAS 76001
 P-O-N-E: (817) 465-5611

TITLE	3.0m GBT
GENERAL ARRANGEMENT	
GBT ELEVATION VIEW	
SIZE	D
DRAWING NUMBER	DMA2787
SCALE	1/16
FILE	DMA2787
SHEET	1
REV	0

8 7 6 5 4 3 2 1

D

D



PLAN VIEW

C

C

B

B

A

A

THIS DRAWING IS COPY RIGHTED
 THIS DRAWING IS A TRADE SECRET AND ONLY ENTRUSTED TO THE RECEIVER
 FOR HIS PERSONAL USE. WITHOUT THE SIGNED WRITTEN CONSENT OF ANDRITZ
 SEPARATION, INC., IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD
 PARTIES, INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES.
 ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS
 RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING
 MUST BE RETURNED ON REQUEST OF THE COMPANY.

FOR REVIEW
 NOT FOR CONSTRUCTION

AST No. -		
ESTIMATED WEIGHT IN LBS: -	DRAWN BY: QG	DATE 03/11/20
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES	CHECKED BY:	DATE
FABRICATION TOLERANCES .XXX±.040 ANG±1° HOLE±.020	APPROVED BY: JL	DATE 03/16/20
MACHINING TOLERANCES .XXX±.005 ANG±.5° HOLE±.020	THIRD ANGLE PROJECTION	
MILL FINISH ALL OVER		

ANDRITZ
 ANDRITZ SEPARATION, INC.
 1010 COMMERCIAL BLVD. SOUTH
 ARLINGTON, TEXAS 76001
 PHONE: (817) 465-5611

TITLE 2.0m QUANTUM GBT		
GENERAL ARRANGEMENT		
SIZE D	DRAWING NUMBER DMA2819	REV 0
SCALE 1/16	FILE DMA2819	SHEET 2 OF 2


8 7 6 5 4 3 2 1

- 1.0 FRAME ASSEMBLY
- 2.0 ROLL ASSEMBLY
 - 2.1 DRIVE ROLL ASSEMBLY
 - 2.2 TENSION ROLL ASSEMBLY
 - 2.3 TRACKING ROLL ASSEMBLY
- 3.0 BELT TENSION ASSEMBLY
- 4.0* TRACKING ASSEMBLY
- 5.0 FILTRATE PAN ASSEMBLY
 - 5.1 BELT ACCESS WINDOWS
- 6.0* SHOWER ASSEMBLY
 - 6.1 SHOWER WATER DRAIN CONNECTION, BOTH SIDES, 2" MNPT.
- 7.0* BELT DOCTOR ASSEMBLY
- 8.0 HEADBOX ASSEMBLY
 - 8.1 RETENTION TANK
 - 8.2 RETENTION TANK DRAIN, 2" MNPT, BOTH SIDES
- 10.0 GRID ASSEMBLY (NOT SHOWN)
- 13.0* DRIVE ASSEMBLY
- 15.0 PLOW ASSEMBLY
 - 15.1* PLOW HANDLES (NOT SHOWN)
- 20.0 FILTRATE DRAIN, 0.8" O.D. (BOTH SIDES)
- 21.0* SHOWER INLET PIPING, 2" FNPT, DRIVE SIDE
- 23.0* HYDRAULIC COMPONENTS
 - 23.1 HYDRAULIC MANIFOLD
 - 23.2 MOTOR/PUMP
 - 23.3 FILTER
 - 23.4 RESERVOIR
- 25.0 VENTURI MIXER ASSEMBLY
- 40.0 BELT

* ITEMS MARKED WITH AN * CHANGE SIDES WITH MACHINE HANDINESS.

MINIMUM UTILITIES REQUIRED:

- 1. ELECTRICAL:
 - 1.1. MAIN MOTOR: 3 HP - 480V/3PH/60HZ
 - 1.2. HYDRAULIC PUMP MOTOR: 1 HP - 480V/3PH/60HZ
- 2. WATER:
 - 2.1. WASH WATER: 69 GAL/MIN [262 L/MIN] AT AMBIENT TEMPERATURE AND 120 PSIG [828 kPA], FILTERED TO 200 MICRONS.
- 3. DRY WEIGHT OF THE MACHINE: 11,030 LBS [5,000 kg]
- 4. WET WEIGHT OF THE MACHINE: 12,130 LBS [5,500 kg]



ELEVATION VIEW

NOTES:

1. FINAL ROUTING OF SLUDGE FEED PIPING BY OTHERS. SLUDGE FEED PIPING IS TO BE SUPPORTED BY OTHERS. FLEXIBLE CONNECTION MUST BE INSTALLED TO ISOLATE MACHINE FROM PIPING MOVEMENT. SLUDGE FEED PIPING AND FLEXIBLE CONNECTION TO BE SUPPLIED BY OTHERS.
2. VENTURI MIXER LOCATED APPROXIMATELY 15 FEET UPSTREAM FROM THE INLET FLANGE. PROVISIONS (SPOOL PIECES) SHOULD BE MADE IN THE SUPPLY PIPING FOR ALTERNATE DISTANCES OF 30 FEET AND 45 FEET.
3. FILTRATE DRAIN PIPING INSTALLATION BY OTHER THAN ANDRITZ.
4. HEIGHT WILL VARY ACCORDING TO THICKENED SLUDGE HANDLING EQUIPMENT. FOUNDATION DETAILS SHOWN ON DRAWING DMF1522.
5. MAINTENANCE PLATFORM BY OTHER THAN ANDRITZ. RECOMMENDED TOP OF GRATING TO BE LEVEL WITH TOP OF FOUNDATION PIERS.
6. RH MACHINE AS SHOWN.
LH MACHINE OPPOSITE AS SHOWN.

THIS DRAWING IS COPY RIGHTED
THIS DRAWING IS A TRADE SECRET AND ONLY ENTRUSTED TO THE RECEIVER FOR HIS PERSONAL USE. WITHOUT THE WRITTEN CONSENT OF ANDRITZ SEPARATION, INC., IT MUST NOT BE COPIED NOR MADE AVAILABLE TO THIRD PARTIES, INCLUDING COMPETITORS, NOR MADE ACCESSIBLE TO SUCH PARTIES. ANY ILLEGAL USE BY THE RECEIVER OR THIRD PARTIES FOR WHICH HE IS RESPONSIBLE CAN CONSTITUTE A CAUSE FOR LEGAL ACTION. THIS DRAWING MUST BE RETURNED ON REQUEST OF THE COMPANY.

SIMILAR TO DMA2808

FOR REVIEW
NOT FOR CONSTRUCTION

AST No. -

ESTIMATED WEIGHT IN LBS: -	DRAWN BY: QG	DATE 03/11/20
UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES	CHECKED BY:	DATE
FABRICATION TOLERANCES .XXX±.040 ANG±1° HOLE±.020	APPROVED BY: JCN	DATE 03/16/20
MACHINING TOLERANCES .XXX±.005 ANG±.5° HOLE±.020	THIRD ANGLE PROJECTION	
MILL FINISH ALL OVER		

ANDRITZ
ANDRITZ SEPARATION, INC.
1010 COMMERCIAL BLVD. SOUTH
ARLINGTON, TEXAS 76001
PHONE: (817) 465-5611

TITLE 2.0m QUANTUM GBT		
GENERAL ARRANGEMENT		
SIZE D	DRAWING NUMBER DMA2819	REV 0
SCALE 1/16	FILE DMA2819	SHEET 1 OF 2

Appendix C. Capital Cost Estimates

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

OPCC

Thickening Alternatives	Equipment	Number of Units
1a, 2a, 3a, 3b	2M GBT	5
1a, 2a, 3a, 3b	RDT	5
1b, 2b	RDT	6

Gravity Thickener Rehabilitation	Equipment	Number of Units
Alternative 1	GVT	2
Alternative 2	GVT	4

Thickened Well Modifications	Equipment	Number of Units
Alternative 1		

Construction Cost	Project Cost
\$5,455,000	\$6,819,000
\$5,230,000	\$6,538,000
\$6,227,000	\$7,784,000

Construction Cost	Project Cost
\$3,365,000	\$4,206,000
\$6,683,000	\$8,354,000

Construction Cost	Project Cost
\$1,142,000	\$1,428,000

Package
Package 1a
Package 1b
Package 2a
Package 2b
Package 3a
Package 3b
Additional Package 1
Additional Package 2
Additional Package 3

Project Costs

-15%	+25%	OPCC
\$5,676,725.00	\$8,348,125.00	\$6,678,500.00
\$6,616,400.00	\$9,730,000.00	\$7,784,000.00
\$5,676,725.00	\$8,348,125.00	\$6,678,500.00
\$6,616,400.00	\$9,730,000.00	\$7,784,000.00
\$5,676,725.00	\$8,348,125.00	\$6,678,500.00
\$5,676,725.00	\$8,348,125.00	\$6,678,500.00
\$3,575,100.00	\$5,257,500.00	\$4,206,000
\$7,100,900.00	\$10,442,500.00	\$8,354,000
\$1,213,800.00	\$1,785,000.00	\$1,428,000

Package 1a, 3a, 3b
Additional Package 1
Additional Package 3
Total Thickening Infrastructure Package

Contractor Overhead and Profit	25%
Contingency	50%
Engineering	25%

Quantity Estimate			
	Units	Rate	Notes
<i>Sitework</i>			
Sitework for buildings	SF	\$ -	
Excavation	CY	\$ -	
Backfill	CY	\$ -	
	CY	\$ -	
	SF	\$ -	
<i>Steel and Concrete</i>			
Building Cost "large"	SF	\$ -	Approximat
Building Cost "small"	SF	\$ -	Approximat
	CY	\$ -	
	SF	\$ -	
<i>Equipment</i>			
	EA	\$ -	
	EA	\$ -	
	EA	\$ -	
	EA	\$ -	

te cost per SF
te cost per SF

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Base Costs
OPCC**

	Qty	Units	Rate
<i>Demolition</i>			
Demo GBTs and Centrifuge	4	EA	\$ 45,000
Demo Thickening Feed Pumps	3	EA	\$ 25,000
Demo GBT/Centrifuge Platforms and Stairways	1	LS	\$ 20,000
<i>Concrete</i>			
GBT Equipment Curbs		EA	\$ 5,000
RDT Pads		EA	\$ 2,500
Centrifugal Pump Pads		EA	\$ 2,500
<i>Metals</i>			
GBT Platform - 5 GBTs	1,500	SF	\$ 95
RDT Platform - 6 RDTs	3,000	SF	\$ 95
RDT Platform - 5 RDTs	2,500	SF	\$ 95
GBT Odor Management	1	LS	\$ 45,000
RDT Odor Management	1	LS	\$ 25,000
<i>Mechanical</i>			
<i>Equipment</i>			
Primary Feed Pump - Centrifugal		EA	\$ 50,000
Thickening Feed Pump - Centrifugal		EA	\$ 50,000

Cost	Notes
\$ 180,000	All demo costs are swags
\$ 75,000	
\$ 20,000	
\$ -	Assume 1-foot tall curb 6" wide, cost from O'Brien
\$ -	Assume 6" pad, cost from O'Brien (with increase), 7 pumps
\$ -	Assume 6" pad, cost from O'Brien (with increase), 7 pumps
\$ 142,500	5 - 2.0 GBTs Platform cost from Glenbard, includes handrails
\$ 285,000	6 RDTs Platform cost from Glenbard, includes handrails
\$ 237,500	5 RDTs Platform cost from Glenbard, includes handrails
\$ 45,000	swag
\$ 25,000	swag
\$ -	Cost from Escanaba
\$ -	500-700 gpm per pump, cost from Escanaba

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Package 1 Five 2M GBT
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo GBTs and Centrifuge	4	EA	\$ 45,000	\$ 180,000
Demo Thickening Feed Pumps	3	EA	\$ 25,000	\$ 75,000
Demo GBT/Centrifuge Platforms and Stairways	1	LS	\$ 20,000	\$ 20,000
Total				\$ 275,000
<i>Concrete</i>				
GBT Equipment Curbs	5	EA	\$ 5,000	\$ 25,000
Centrifugal Pump Pads	4	EA	\$ 2,500	\$ 10,000
Total				\$ 35,000
<i>Metals</i>				
GBT Platform - 5 GBTs	1,500	SF	\$ 95	\$ 142,500
GBT Odor Management	1	LS	\$ 45,000	\$ 45,000
Total				\$ 187,500
<i>Mechanical</i>				
Total				\$ -
<i>Equipment</i>				
Thickening Feed Pump - Centrifugal	4	EA	\$ 50,000	\$ 200,000
2M GBT	5	EA	\$ 225,000	\$ 1,125,000
Install			30%	\$ 397,500
Subtotal				\$ 1,722,500
Mechanical			20%	\$ 344,500
Electrical & I&C			20%	\$ 344,500
Total				\$ 2,411,500
Subtotal				\$ 2,909,000
Contractor Overhead and Profit			25%	\$ 727,300
Subtotal				\$ 3,636,300
Contingency			50%	\$ 1,818,200
Total Construction Cost				\$ 5,455,000
Engineering			25%	\$ 1,363,800
Total Cost				\$ 6,819,000

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Package 1 Five RDT
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo GBTs and Centrifuge	4	EA	\$ 45,000	\$ 180,000
Demo Thickening Feed Pumps	3	EA	\$ 25,000	\$ 75,000
Demo GBT/Centrifuge Platforms and Stairways	1	LS	\$ 20,000	\$ 20,000
Total				\$ 275,000
<i>Concrete</i>				
RDT Pads	5	EA	\$ 2,500	\$ 12,500
Centrifugal Pump Pads	4	EA	\$ 2,500	\$ 10,000
Total				\$ 22,500
<i>Metals</i>				
RDT Platform - 5 RDTs	2,500	SF	\$ 95	\$ 237,500
RDT Odor Management	1	LS	\$ 25,000	\$ 25,000
Total				\$ 262,500
<i>Mechanical</i>				
Total				\$ -
<i>Equipment</i>				
Thickening Feed Pump - Centrifugal	4	EA	\$ 50,000	\$ 200,000
RDT	5	EA	\$ 205,000	\$ 1,025,000
Install			30%	\$ 367,500
Subtotal				\$ 1,592,500
Mechanical			20%	\$ 318,500
Electrical & I&C			20%	\$ 318,500
Total				\$ 2,229,500
Subtotal				\$ 2,789,500
Contractor Overhead and Profit			25%	\$ 697,400
Subtotal				\$ 3,486,900
Contingency			50%	\$ 1,743,500
Total Construction Cost				\$ 5,230,000
Engineering			25%	\$ 1,307,500
Total Cost				\$ 6,538,000

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Package 2 Six RDT
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo GBTs and Centrifuge	4	EA	\$ 45,000	\$ 180,000
Demo Thickening Feed Pumps	3	EA	\$ 25,000	\$ 75,000
Demo GBT/Centrifuge Platforms and Stairways	1	LS	\$ 20,000	\$ 20,000
Total				\$ 275,000
<i>Concrete</i>				
RDT Pads	6	EA	\$ 5,000	\$ 30,000
Centrifugal Pump Pads	5	EA	\$ 2,500	\$ 12,500
Total				\$ 42,500
<i>Metals</i>				
RDT Platform - 6 RDTs	3,000	#REF!	\$ 95	\$ 285,000
RDT Odor Management	1	LS	\$ 25,000	\$ 25,000
Total				\$ 310,000
<i>Mechanical</i>				
Total				\$ -
<i>Equipment</i>				
Thickening Feed Pump - Centrifugal	5	EA	\$ 50,000	\$ 250,000
RDT	6	EA	\$ 205,000	\$ 1,230,000
Install			30%	\$ 444,000
Subtotal				\$ 1,924,000
Mechanical			20%	\$ 384,800
Electrical & I&C			20%	\$ 384,800
Total				\$ 2,693,600
Subtotal				\$ 3,321,100
Contractor Overhead and Profit			25%	\$ 830,300
Subtotal				\$ 4,151,400
Contingency			50%	\$ 2,075,700
Total Construction Cost				\$ 6,227,000
Engineering			25%	\$ 1,556,800
Total Cost				\$ 7,784,000

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Additional Package 1 - Two Gravity Thickener Rehabilitation
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo Primary Feed Pumps	3	EA	\$ 25,000	\$ 75,000
Remove existing covers (2 Total)	3,927	SF	\$ 7	\$ 25,525
Remove existing mechanisms (2 Total)	2	EA	\$ 40,000	\$ 80,000
Total				\$ 180,525
<i>Concrete</i>				
Centrifugal Pump Pads	3	EA	\$ 2,500	\$ 7,500
Surface Cleaning	2	EA	\$ 10,000	\$ 20,000
Concrete Repairs	2	EA	\$ 50,000	\$ 100,000
Total				\$ 127,500
<i>Metals</i>				
Total				\$ -
<i>Mechanical</i>				
Piping for Primary Sludge in tunnel	500	LF	\$ 50	\$ 25,000
Total				\$ 25,000
<i>Equipment</i>				
Primary Feed Pump - Centrifugal	3	EA	\$ 50,000	\$ 150,000
Aluminum Covers (45-50ft diameter)	2	EA	\$ 101,500	\$ 203,000
Circular Gravity Thickener Equipment	2	EA	\$ 225,000	\$ 450,000
Install			30%	\$ 240,900
Subtotal				\$ 1,043,900
Mechanical			20%	\$ 208,780
Electrical & I&C			20%	\$ 208,780
Total				\$ 1,461,460
Subtotal				\$ 1,794,500
Contractor Overhead and Profit			25%	\$ 448,600
Subtotal				\$ 2,243,100
Contingency			50%	\$ 1,121,600
Total Construction Cost				\$ 3,365,000
Engineering			25%	\$ 841,300
Total Cost				\$ 4,206,000

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Additional Package 2 - Four Gravity Thickener Rehabilitation
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo Primary Feed Pumps	6	EA	\$ 25,000	\$ 150,000
Remove existing covers (4 Total)	7,854	SF	\$ 7	\$ 51,051
Remove existing mechanisms (4Total)	4	EA	\$ 40,000	\$ 160,000
Total				\$ 361,051
<i>Concrete</i>				
Centrifugal Pump Pads	6	EA	\$ 2,500	\$ 15,000
Surface Cleaning	4	EA	\$ 10,000	\$ 40,000
Concrete Repairs	4	EA	\$ 50,000	\$ 200,000
Total				\$ 255,000
<i>Metals</i>				
Total				\$ -
<i>Mechanical</i>				
Piping for Primary Sludge in tunnel	500	LF	\$ 50	\$ 25,000
Total				\$ 25,000
<i>Equipment</i>				
Primary Feed Pump - Centrifugal	6	EA	\$ 50,000	\$ 300,000
Aluminum Covers (45-50ft diameter)	4	EA	\$ 101,500	\$ 406,000
Circular Gravity Thickener Equipment	4	EA	\$ 225,000	\$ 900,000
Install			30%	\$ 481,800
Subtotal				\$ 2,087,800
Mechanical			20%	\$ 417,560
Electrical & I&C			20%	\$ 417,560
Total				\$ 2,922,920
Subtotal				\$ 3,564,000
Contractor Overhead and Profit			25%	\$ 891,000
Subtotal				\$ 4,455,000
Contingency			50%	\$ 2,227,500
Total Construction Cost				\$ 6,683,000
Engineering			25%	\$ 1,670,800
Total Cost				\$ 8,354,000

**NEW Water
Green Bay Facility and De Pere Facility
Facility Plan**

**Additional Package 3 - Thickened Sludge Wet Well and Pumping
OPCC**

	Qty	Units	Rate	Cost
<i>Demolition</i>				
Demo Thickened Feed Pumps	4	EA	\$ 25,000	\$ 100,000
Demo Thickened Feed Well Walls	2	LS	\$ 30,000	\$ 60,000
Total				\$ 160,000
<i>Concrete</i>				
Pumps - Procav Pads	4	EA	\$ 2,500	\$ 10,000
Reslope Exst Feed Wells	15	CY	\$ 5,000	\$ 75,000
Total				\$ 85,000
<i>Metals</i>				
Total				\$ -
<i>Mechanical</i>				
Total				\$ -
<i>Equipment</i>				
Thickened Feed Pumps - ProCav	4	EA	\$ 50,000	\$ 200,000
Install			30%	\$ 60,000
Subtotal				\$ 260,000
Mechanical			20%	\$ 52,000
Electrical & I&C			20%	\$ 52,000
Total				\$ 364,000
Subtotal				\$ 609,000
Contractor Overhead and Profit			25%	\$ 152,300
Subtotal				\$ 761,300
Contingency			50%	\$ 380,700
Total Construction Cost				\$ 1,142,000
Engineering			25%	\$ 285,500
Total Cost				\$ 1,428,000

